



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2104-40473



Request No. : WA-Q-L-2104-05682 Received Date : 03/04/2021 Sample No. : WA-S-L-2104-39977

Sampling Date	: 03/04/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 03/04/2021	Analysis End Date.	: 05/04/2021
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 4275	Sampling Method	: APHA 9060 A&B
Temperature °C	: 27	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Swimming Pool Water
Sampling Point	: FSP	Preservation	: 4-8°C
Sample Description	: Pool Water		

Parameters	Test Methods	Units	Results	Specification
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Escherichia Coli	APHA 9222 B,H&I 23rd Ed. 2017	CFU/100ml	Not Detected	--

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool),
Issued by the Head of Urban Planning and Municipalities No.(3) for the year 2018, Page No.3.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2104-40495



Request No. : WA-Q-L-2104-05682 Received Date : 03/04/2021 Sample No. : WA-S-L-2104-39999

Sampling Date	: 03/04/2021	Report Date.	: 13/04/2021
Analysis Start Date.	: 03/04/2021	Analysis End Date.	: 13/04/2021
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 4275	Sampling Method	: BS 7592
Temperature °C	: 27	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Swimming Pool Water
Sampling Point	: FSP	Preservation	: 10°C
Sample Description	: Pool Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the sample tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

Swimming Pool Analysis Report


CUSTOMER: SERCO MIDDLE EAST			
Site Name:	ZAYED UNIVERSITY	Visit Date:	03-04-2021
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

Test Result			
No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.57
2	Conductivity at 25°C, µs/cm	---	764
3	TDS, ppm	Max 1500	496
4	Alkalinity	80 - 120	91
5	Calcium Hardness	200 - 500	236
6	Residual Chlorine	1.0 - 3.0	1.34
7	Cyanuric Acid	20 - 60	28
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.

Reported By,


Murugaraj
Service Engineer

