



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7209



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7120
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 31.4	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-1
Sampling Point	: GROUND FLOOR COMMUNITY CENTER PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7216



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7127
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 31.4	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-1
Sampling Point	: GROUND FLOOR COMMUNITY CENTER PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7210



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7121
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 32.6	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-2
Sampling Point	: GROUND FLOOR LILI-3 PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7217



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7128
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 32.6	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-2
Sampling Point	: GROUND FLOOR LILI-3 PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7211



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7122
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 34.1	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-ARJWAN-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D
Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7218



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7129
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 34.1	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-ARJWAN-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7212



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7123
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 30.7	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-TULIP-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7219



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7130
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 30.7	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-TULIP-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7213



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7124
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 34.9	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-ORCHID-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D
Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7220



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7131
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 34.9	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-ORCHID-3
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7214



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7125
Sampling Date/time	: 14/4/2020 , 14:06	Report Date.	: 16/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 16/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: APHA 9060 A & B
Temperature °C	: 32.1	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-YASMIN
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 4-8°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7221



Request No.	: WA-Q-L-2004-1146	Sample No.	: WA-S-L-2004-7132
Sampling Date/time	: 14/4/2020 , 14:08	Report Date.	: 25/4/2020
Analysis Start Date.	: 14/4/2020	Analysis End Date.	: 24/4/2020
Sample Location.	: TAWAFUQ AL RAYYANA, KHALIFA CITY	Sampled By	: Jameel
Sample Identification	: N/A	Sample Submitted as	: WATER
Sample Certificate No	: 0384	Sampling Method	: BS 7592
Temperature °C	: 32.1	Site Observation	: CLEAR
Sampling Container	: STERILE PLASTIC BOTTLE	Source of Sample	: RCC WATER TANK-YASMIN
Sampling Point	: GROUND FLOOR PUMP ROOM	Preservation	: 10°C
Sample Description	: WATER		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -