

TEST REPORT

REPORT NO:-QMTL/R-84475

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84475
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Main Water Tank Sample Onsite Temp: 25.5°C Sample Receipt Temp: 4°C	Source: Tank	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.07 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84476

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E
Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84476
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Filter Water Tank: 1 Sample Onsite Temp: 25.4°C Sample Receipt Temp: 4°C	Source: Tank	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.23 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84477

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84476
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Filter Water Tank: 2 Sample Onsite Temp: 25.7°C Sample Receipt Temp: 4°C	Source: Tank	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.47 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84471

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84471
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Pantry- Cold Water Sample Onsite Temp: 23.7°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.27 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84472

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84472
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Kitchen- Cold Water Sample Onsite Temp: 24.7°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.35 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84473

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84473
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Male Wash Room- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.49 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84474

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84474
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Mezzanine Floor, Male Wash Room- Cold Water Sample Onsite Temp: 23°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.58 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84489

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84489
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Main Water Tank Sample Onsite Temp: 25.5°C Sample Receipt Temp: 16°C	Source: Tank	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.07 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84490

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84490
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Filter Water Tank: 1 Sample Onsite Temp: 25.4°C Sample Receipt Temp: 16°C	Source: Tank	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.23 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84491

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84491
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Filter Water Tank: 2 Sample Onsite Temp: 25.7°C Sample Receipt Temp: 16°C	Source: Tank	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.47 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84485

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84485
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Pantry- Cold Water Sample Onsite Temp: 23.7°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.27 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84486

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84486
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Kitchen- Cold Water Sample Onsite Temp: 24.7°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.35 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84487

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84487
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Ground Floor, Male Wash Room- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.49 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84488

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84488
Reference: ADIA – BRC	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Mezzanine Floor, Male Wash Room- Cold Water Sample Onsite Temp: 23°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/09.58 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomphila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomphila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Ground Floor -Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.21
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	218
3	Total Dissolved Solids (TDS)	Max 1000	133
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.16
7	Calcium Hardness at 25°C	200	47
8	Total Hardness at 25°C	300	56


Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	41
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

 Murugaraaj
 Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Ground Floor Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.12
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	228
3	Total Dissolved Solids (TDS)	Max 1000	148
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.15
7	Calcium Hardness at 25°C	200	49
8	Total Hardness at 25°C	300	54

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	32
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

 Murugaraaj
 Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Ground Floor Wash Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.16
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	219
3	Total Dissolved Solids (TDS)	Max 1000	142
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.13
7	Calcium Hardness at 25°C	200	56
8	Total Hardness at 25°C	300	52

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	31
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj

Service Engineer



POTABLE WATER ANALYSIS REPORT


Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Mezzanine Floor Wash Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.23
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	215
3	Total Dissolved Solids (TDS)	Max 1000	139
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.15
7	Calcium Hardness at 25°C	200	58
8	Total Hardness at 25°C	300	63
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	39
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

 Murugaraaj
 Service Engineer

