

TEST REPORT

REPORT NO:-QMTL/R-85242

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S-85242
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received : 18.12.2019
Sample Description : SV1 ETS Room, Chilled Water Sample Onsite Temp: 10.3°C Sample Receipt Temp: 6°C	Source: Valve	Date(s) Tested : 18-20.12.2019
	Sample Container: 1X 500ml PB	Date Reported : 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 18.12.2019/01.37 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10,000	9
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-85234

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S-85234
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received : 18.12.2019
Sample Description : SV2, ETS Room, Chilled Water Sample Onsite Temp: 12°C Sample Receipt Temp: 5°C	Source: Valve	Date(s) Tested : 18-20.12.2019
	Sample Container: 1X 500ml PB	Date Reported : 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 18.12.2019/11.30 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10,000	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-85236

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S-85236
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received : 18.12.2019
Sample Description : Male Side M1 Building Plant Room, Chilled Water Roof Sample Onsite Temp: 9°C Sample Receipt Temp: 5°C	Source: Valve	Date(s) Tested : 18-20.12.2019
	Sample Container: 1X 500ml PB	Date Reported : 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 18.12.2019/11.50 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10,000	8
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-85240

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S-85240
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received : 18.12.2019
Sample Description : Female Side Plant Room, FF2- Chilled Water Roof Sample Onsite Temp: 11°C Sample Receipt Temp: 5°C	Source: Valve	Date(s) Tested : 18-20.12.2019
	Sample Container: 1X 500ml PB	Date Reported : 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 18.12.2019/01.04 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10,000	5
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016