



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9505

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1497	Sample No.	: WA-S-L-2005-9306
Sampling Date/time	: 19/5/2020 , 14:20	Report Date.	: 22/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 21/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Sugeeth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0905	Sampling Method	: APHA 9060 A&B
Temperature °C	: 21.3°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Cooking Area Cold Water Tap
Sampling Point	: P2 Kitchen	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml#
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml#
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

#Limit based on HAAD/HED/ST/0012/HS\_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2005-9505

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2005-9519

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1497	Sample No.	: WA-S-L-2005-9320
Sampling Date/time	: 19/5/2020 , 14:20	Report Date.	: 22/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 21/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Sugeeth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0908	Sampling Method	: APHA 9060 A&B
Temperature °C	: 26°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: P1 Male Physio Wash Room WB Cold Water
Sampling Point	: Cold Water from Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml#
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml#
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

#Limit based on HAAD/HED/ST/0012/HS\_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9519

Signed for and on behalf of Wimpey Laboratories



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

**Crystalline Environmental Services**

Report No. WA-R-L-2005-9517



Request No.	: WA-Q-L-2005-1497	Sample No.	: WA-S-L-2005-9318
Sampling Date/time	: 19/5/2020 , 14:20	Report Date.	: 22/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 21/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Sugeeth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0908	Sampling Method	: APHA 9060 A&B
Temperature °C	: 20.6°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: P2 Staff Wash Room Cold Water
Sampling Point	: Cold Water from Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml#
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml#
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

#Limit based on HAAD/HED/ST/0012/HS\_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9517

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.  
This report shall not be reproduced except in full, without the written approval of the Laboratory.  
This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

**Crystalline Environmental Services**

Report No. WA-R-L-2005-9521



Request No.	: WA-Q-L-2005-1497	Sample No.	: WA-S-L-2005-9322
Sampling Date/time	: 19/5/2020 , 14:20	Report Date.	: 22/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 21/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Sugeeth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0908	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23.7°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: L3 Ward PAT Room (Any of One) WB Cold Water
Sampling Point	: Cold Water from Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml#
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml#
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

#Limit based on HAAD/HED/ST/0012/HS\_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034  
Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9521

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9523



Request No.	: WA-Q-L-2005-1497	Sample No.	: WA-S-L-2005-9324
Sampling Date/time	: 19/5/2020 , 14:20	Report Date.	: 22/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 21/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Sugeeth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0909	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22.3°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: L2 Ward PAT Room (Any of One) WB Cold Water
Sampling Point	: Cold Water from Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml#
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml#
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= $\leq$ 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

#Limit based on HAAD/HED/ST/0012/HS\_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذم م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034  
Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9523

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -