

TEST REPORT

Report No: QMTL/R-140201/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140201
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 26 Dec 2020
		Date Reported	02 Jan 2021
Sample Description	OT		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020/10:15 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	18°C	Sample Onsite Temp	21.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	247.2@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	7.54@24.2°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
CHEMICAL PARAMETERS				
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	42.8
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	66.2
METALS				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	22.4
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-140202/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140202
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 26 Dec 2020
		Date Reported	02 Jan 2021
Sample Description	DSU		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020/10:32 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	18°C	Sample Onsite Temp	30.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	248.7@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	7.64@24.2°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
CHEMICAL PARAMETERS				
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	45.2
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	65.1
METALS				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	24.3
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	13
------------------------	----

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
-----------------------------------------------------------------------------	--

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-140203/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140203
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 26 Dec 2020
		Date Reported	02 Jan 2021
Sample Description	RO		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020/10:15 AM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	18°C	Sample Onsite Temp	15.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	12.5@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	8.02@24.2°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
CHEMICAL PARAMETERS				
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	<3
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	<3
METALS				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	<3
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	13
------------------------	----

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-140204/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-140204	
	Date Received	23 Dec 2020	
	Date(s) Tested	23 Dec 2020 - 26 Dec 2020	
	Date Reported	02 Jan 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level 1, CSSD- Decontamination Room's Sink		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020/10:15 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	18°C	Sample Onsite Temp	19.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	7.81@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	248@24.2°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
CHEMICAL PARAMETERS				
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	44.7
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	64.2
METALS				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	22.8
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT