

TEST REPORT

REPORT NO: - QMTL/R-89324

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89324
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 01 Sample Onsite Temp: 23.8°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:33PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89323

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89323
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 02 Sample Onsite Temp: 24°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:03PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89322

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89322
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 03 Sample Onsite Temp: 23.1°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/12:51PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89310

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 89310
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 04 Sample Onsite Temp: 24.1°C Sample Receipt Temp: 5°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-18.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:40PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89309

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 89309
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 05 Sample Onsite Temp: 24.8°C Sample Receipt Temp: 5°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-18.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:24PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89308

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 89308
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 06 Sample Onsite Temp: 25°C Sample Receipt Temp: 5°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-18.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:16PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health - Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89325

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89325
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 07 Sample Onsite Temp: 23.9°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:53PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89311

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 89311
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 08 Sample Onsite Temp: 24°C Sample Receipt Temp: 5°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-18.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:45PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89328

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89328
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 09 Sample Onsite Temp: 23.9°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/02:18PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89327

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89327
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 10 Sample Onsite Temp: 25.8°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/02:07PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced, (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89312

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 89312
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room 10A VIP Sample Onsite Temp: 24°C Sample Receipt Temp: 5°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-18.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/02:39PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89326

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89326
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 11 Sample Onsite Temp: 25.8°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/01:58PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-89329

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S- 89329
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 16.01.2020
Sample Description : Dental Room No: 12 Sample Onsite Temp: 23.7°C Sample Receipt Temp: 16°C	Source: Dental Chair Line	Date(s) Tested: 16.01.2020-26.01.2020
	Sample Container: 1x1 L PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 16.01.2020/02:50PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT