

## TEST REPORT

Report No: QMTL/R-92891/2020

|   |   |                           |                     |
|---|---|---------------------------|---------------------|
| <b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates<br><br><b>ATTN</b> : MR. JASMAN PINTO | Sample ID   | QMTL/S-92891              |                     |
|   | Date Received   | 10 Feb 2020               |                     |
|   | Date(s) Tested  | 10 Feb 2020 - 12 Feb 2020 |                     |
|   | Date Reported   | 20 Feb 2020               |                     |
| Sample Description  | A6 Building, Drinking Fountain Level Ground banquet Wash Area |                           |                     |
| Sample Type   | Water   | Sampling Method           | QMTL-WI-15          |
| Client Name/Project   | NP  | Sampled By                | QMTL Representative |
| Location  | AUH   | Sampling Date/Time        | 10.02.2020/2:45 PM  |
| Sample Container  | 1x500mL PB  | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp   | 4°C   | Sample Onsite Temp        | 23.9°C              |
| Sample Appearance   | Clear   | On-site Treatment         | NP                  |
| Reference   | NYUAD   |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable |
|----------|--|

|                         |              |
|-------------------------|--------------|
| Test method deviation   | None         |
| Test performed by Emp#  | 78 & 74 & 55 |
| Report prepared by Emp# | 22           |

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-92870/2020

|  |                               |                           |                     |
|--|-------------------------------|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                     | QMTL/S-92870              |                     |
|  | Date Received                 | 10 Feb 2020               |                     |
|  | Date(s) Tested                | 10 Feb 2020 - 12 Feb 2020 |                     |
|  | Date Reported                 | 20 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |                               |                           |                     |
| Sample Description   | Baby Care Center - Kitchen B2 |                           |                     |
| Sample Type  | Water                         | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP                            | Sampled By                | QMTL Representative |
| Location   | AUH                           | Sampling Date/Time        | 10.02.2020/9:00 AM  |
| Sample Container   | 1x500mL PB                    | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 4°C                           | Sample Onsite Temp        | 23.8°C              |
| Sample Appearance  | Clear                         | On-site Treatment         | NP                  |
| Reference  | NYUAD                         |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable |
|----------|--|

|                       |      |
|-----------------------|------|
| Test method deviation | None |
|-----------------------|------|

|                        |              |
|------------------------|--------------|
| Test performed by Emp# | 78 & 74 & 55 |
|------------------------|--------------|

|                         |    |
|-------------------------|----|
| Report prepared by Emp# | 22 |
|-------------------------|----|

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93054/2020

|  |   |                           |                     |
|--|---|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID   | QMTL/S-93054              |                     |
|  | Date Received   | 11 Feb 2020               |                     |
|  | Date(s) Tested  | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported   | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |   |                           |                     |
| Sample Description   | C1 Building, Ground Level, ERB Kitchen, Food Preparation Area |                           |                     |
| Sample Type  | Water   | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP  | Sampled By                | QMTL Representative |
| Location   | AUH   | Sampling Date/Time        | 11.02.2020/01:40 PM |
| Sample Container   | 1x500ml PB  | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C   | Sample Onsite Temp        | 23.8°C              |
| Sample Appearance  | Clear   | On-site Treatment         | NA                  |
| Reference  | NYUAD   |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|                         |         |
|-------------------------|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp# | 22      |

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93055/2020

|  |  |                           |                     |
|--|--|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID  | QMTL/S-93055              |                     |
|  | Date Received  | 11 Feb 2020               |                     |
|  | Date(s) Tested                                       | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported  | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |
| Sample Description   | C1 Building, Level Ground, ERB Kitchen, Serving Area |                           |                     |
| Sample Type  | Water  | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP   | Sampled By                | QMTL Representative |
| Location   | AUH  | Sampling Date/Time        | 11.02.2020/02:00 PM |
| Sample Container   | 1x500ml PB   | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C  | Sample Onsite Temp        | 24°C                |
| Sample Appearance  | Clear  | On-site Treatment         | NA                  |
| Reference  | NYUAD  |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93045/2020

|  |  |                           |                     |
|--|--|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                                      | QMTL/S-93045              |                     |
|  | Date Received                                  | 11 Feb 2020               |                     |
|  | Date(s) Tested                                 | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                                  | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |
| Sample Description   | C2 Building, Health & Wellness Center, Kitchen |                           |                     |
| Sample Type  | Water  | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP   | Sampled By                | QMTL Representative |
| Location   | AUH  | Sampling Date/Time        | 11.02.2020/10:55 AM |
| Sample Container   | 1x500ml PB                                     | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C  | Sample Onsite Temp        | 23°C                |
| Sample Appearance  | Clear  | On-site Treatment         | NA                  |
| Reference  | NYUAD  |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | 5       |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By



ANILA GEORGE  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93046/2020

|  |  |                           |                     |  |
|--|--|---------------------------|---------------------|--|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID  | QMTL/S-93046              |                     |  |
|  | Date Received                                    | 11 Feb 2020               |                     |  |
|  | Date(s) Tested                                   | 11 Feb 2020 - 13 Feb 2020 |                     |  |
|  | Date Reported                                    | 24 Feb 2020               |                     |  |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |  |
| Sample Description   | C2 Building, Health & Wellness Center, Wash Room |                           |                     |  |
| Sample Type  | Water  | Sampling Method           | QMTL-WI-15          |  |
| Client Name/Project  | NP   | Sampled By                | QMTL Representative |  |
| Location   | AUH  | Sampling Date/Time        | 11.02.2020/11:20 AM |  |
| Sample Container   | 1x500ml PB                                       | Sampling Point            | Tap ( Sink )        |  |
| Sample Receipt Temp  | 5°C  | Sample Onsite Temp        | 23.2°C              |  |
| Sample Appearance  | Clear  | On-site Treatment         | NA                  |  |
| Reference  | NYUAD  |                           |                     |  |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93047/2020

|  |  |                           |                     |
|--|--|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                                | QMTL/S-93047              |                     |
|  | Date Received                            | 11 Feb 2020               |                     |
|  | Date(s) Tested                           | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                            | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |
| Sample Description   | C2 Building, Level-01, Convenience Store |                           |                     |
| Sample Type  | Water                                    | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP                                       | Sampled By                | QMTL Representative |
| Location   | AUH                                      | Sampling Date/Time        | 11.02.2020/11:43 AM |
| Sample Container   | 1x500ml PB                               | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C                                      | Sample Onsite Temp        | 23.9°C              |
| Sample Appearance  | Clear                                    | On-site Treatment         | NA                  |
| Reference  | NYUAD                                    |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |   |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|---|

|                         |         |
|-------------------------|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp# | 22      |

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93050/2020

|  |  |                           |                     |
|--|--|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID  | QMTL/S-93050              |                     |
|  | Date Received                                    | 11 Feb 2020               |                     |
|  | Date(s) Tested                                   | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                                    | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |
| Sample Description   | C2 Building, Level 02, SMP Food Preparation Area |                           |                     |
| Sample Type  | Water  | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP   | Sampled By                | QMTL Representative |
| Location   | AUH  | Sampling Date/Time        | 11.02.2020/12:36 PM |
| Sample Container   | 1x500ml PB                                       | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C  | Sample Onsite Temp        | 24.5°C              |
| Sample Appearance  | Clear  | On-site Treatment         | NA                  |
| Reference  | NYUAD  |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|                         |         |
|-------------------------|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp# | 22      |

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in writing) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93051/2020

|  |  |                           |                     |
|--|--|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID  | QMTL/S-93051              |                     |
|  | Date Received                                      | 11 Feb 2020               |                     |
|  | Date(s) Tested                                     | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                                      | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |  |                           |                     |
| Sample Description   | C2 Building, Level 02, EL Fuego, Kitchen Hand Wash |                           |                     |
| Sample Type  | Water  | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP   | Sampled By                | QMTL Representative |
| Location   | AUH  | Sampling Date/Time        | 11.02.2020/12:50 PM |
| Sample Container   | 1x500ml PB   | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C  | Sample Onsite Temp        | 24.8°C              |
| Sample Appearance  | Clear  | On-site Treatment         | NA                  |
| Reference  | NYUAD  |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (electronically or otherwise) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93053/2020

|  |                                     |                           |                     |
|--|-------------------------------------|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                           | QMTL/S-93053              |                     |
|  | Date Received                       | 11 Feb 2020               |                     |
|  | Date(s) Tested                      | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                       | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |                                     |                           |                     |
| Sample Description   | C2 Building, Level 03, Library Cafe |                           |                     |
| Sample Type  | Water                               | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP                                  | Sampled By                | QMTL Representative |
| Location   | AUH                                 | Sampling Date/Time        | 11.02.2020/01:28 PM |
| Sample Container   | 1x500ml PB                          | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C                                 | Sample Onsite Temp        | 24.8°C              |
| Sample Appearance  | Clear                               | On-site Treatment         | NA                  |
| Reference  | NYUAD                               |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93058/2020

|  |                             |                           |                     |
|--|-----------------------------|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                   | QMTL/S-93058              |                     |
|  | Date Received               | 11 Feb 2020               |                     |
|  | Date(s) Tested              | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported               | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |                             |                           |                     |
| Sample Description   | D1 Kitchen, Grill Hand Wash |                           |                     |
| Sample Type  | Water                       | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP                          | Sampled By                | QMTL Representative |
| Location   | AUH                         | Sampling Date/Time        | 11.02.2020/03:19 PM |
| Sample Container   | 1x500ml PB                  | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C                         | Sample Onsite Temp        | 23.4°C              |
| Sample Appearance  | Clear                       | On-site Treatment         | NA                  |
| Reference  | NYUAD                       |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | 7       |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|                         |         |
|-------------------------|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp# | 22      |

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93059/2020

|   |  |   |
|---|--|---|
| <b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates<br><br><b>ATTN</b> : MR. JASMAN PINTO | Sample ID                                | QMTL/S-93059                              |
|   | Date Received                            | 11 Feb 2020                               |
|   | Date(s) Tested                           | 11 Feb 2020 - 13 Feb 2020                 |
|   | Date Reported                            | 24 Feb 2020                               |
| Sample Description  | <b>D1 Kitchen, Food Preparation Area</b> |   |
| Sample Type   | Water                                    | Sampling Method<br>QMTL-WI-15             |
| Client Name/Project   | NP                                       | Sampled By<br>QMTL Representative         |
| Location  | AUH                                      | Sampling Date/Time<br>11.02.2020/03:30 PM |
| Sample Container  | 1x500ml PB                               | Sampling Point<br>Tap ( Sink )            |
| Sample Receipt Temp   | 5°C                                      | Sample Onsite Temp<br>23.5°C              |
| Sample Appearance   | Clear                                    | On-site Treatment<br>NA                   |
| Reference   | NYUAD                                    |   |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |  |
|----------|--|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable |
|----------|--|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-93040/2020

|  |   |                    |                           |
|--|---|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates |   | Sample ID          | QMTL/S-93040              |
| ATTN : MR. JASMAN PINTO  |   | Date Received      | 11 Feb 2020               |
|  |   | Date(s) Tested     | 11 Feb 2020 - 13 Feb 2020 |
|  |   | Date Reported      | 24 Feb 2020               |
| Sample Description   | D2 Level Ground - Kitchen Food Preparation Area |                    |                           |
| Sample Type  | Water   | Sampling Method    | QMTL-WI-15                |
| Client Name/Project  | NP  | Sampled By         | QMTL Representative       |
| Location   | AUH   | Sampling Date/Time | 11.02.2020/09:33 AM       |
| Sample Container   | 1x500ml PB                                      | Sampling Point     | Tap ( Sink )              |
| Sample Receipt Temp  | 5°C   | Sample Onsite Temp | 23.5°C                    |
| Sample Appearance  | Clear   | On-site Treatment  | NA                        |
| Reference  | NYUAD   |                    |                           |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | 9       |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |   |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|---|

|                       |      |
|-----------------------|------|
| Test method deviation | None |
|-----------------------|------|

|                        |         |
|------------------------|---------|
| Test performed by Emp# | 74 & 78 |
|------------------------|---------|

|                         |    |
|-------------------------|----|
| Report prepared by Emp# | 22 |
|-------------------------|----|

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93041/2020

|   |                                      |                           |                     |
|---|--------------------------------------|---------------------------|---------------------|
| <b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates<br><br><b>ATTN</b> : MR. JASMAN PINTO | Sample ID                            | QMTL/S-93041              |                     |
|   | Date Received                        | 11 Feb 2020               |                     |
|   | Date(s) Tested                       | 11 Feb 2020 - 13 Feb 2020 |                     |
|   | Date Reported                        | 24 Feb 2020               |                     |
| Sample Description  | D2 Level Ground, The Grill Hand Wash |                           |                     |
| Sample Type   | Water                                | Sampling Method           | QMTL-WI-15          |
| Client Name/Project   | NP                                   | Sampled By                | QMTL Representative |
| Location  | AUH                                  | Sampling Date/Time        | 11.02.2020/09:56 AM |
| Sample Container  | 1x500ml PB                           | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp   | 5°C                                  | Sample Onsite Temp        | 23.9°C              |
| Sample Appearance   | Clear                                | On-site Treatment         | NA                  |
| Reference   | NYUAD                                |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |   |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|---|

|                         |         |
|-------------------------|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp# | 22      |

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-93038/2020

|  |   |                           |                     |
|--|---|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID   | QMTL/S-93038              |                     |
|  | Date Received   | 11 Feb 2020               |                     |
|  | Date(s) Tested  | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported   | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |   |                           |                     |
| Sample Description   | D2 Building, Level 01, Torch Club Kitchen, Food Preparation |                           |                     |
| Sample Type  | Water   | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP  | Sampled By                | QMTL Representative |
| Location   | AUH   | Sampling Date/Time        | 11.02.2020/09:00 AM |
| Sample Container   | 1x500ml PB  | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C   | Sample Onsite Temp        | 23.5°C              |
| Sample Appearance  | Clear   | On-site Treatment         | NA                  |
| Reference  | NYUAD   |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | 8       |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |   |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|---|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By



ANILA GEORGE  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-93039/2020

|  |                                       |                           |                     |
|--|---------------------------------------|---------------------------|---------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES<br>Abu Dhabi PO Box : 131463<br>United Arab Emirates | Sample ID                             | QMTL/S-93039              |                     |
|  | Date Received                         | 11 Feb 2020               |                     |
|  | Date(s) Tested                        | 11 Feb 2020 - 13 Feb 2020 |                     |
|  | Date Reported                         | 24 Feb 2020               |                     |
| ATTN : MR. JASMAN PINTO  |                                       |                           |                     |
| Sample Description   | D2 Building, Torch Club, Serving Area |                           |                     |
| Sample Type  | Water                                 | Sampling Method           | QMTL-WI-15          |
| Client Name/Project  | NP                                    | Sampled By                | QMTL Representative |
| Location   | AUH                                   | Sampling Date/Time        | 11.02.2020/09:15 AM |
| Sample Container   | 1x500ml PB                            | Sampling Point            | Tap ( Sink )        |
| Sample Receipt Temp  | 5°C                                   | Sample Onsite Temp        | 23.6°C              |
| Sample Appearance  | Clear                                 | On-site Treatment         | NA                  |
| Reference  | NYUAD                                 |                           |                     |

### TEST RESULTS

| PARAMETERS                      | TEST METHODS   | UNITS      | GUIDELINES | RESULTS |
|---------------------------------|--|------------|------------|---------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |  |            |            |         |
| E.coli                          | APHA 9222 H & I (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Fecal Coliforms                 | APHA 9222 D (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Pseudomonas aeruginosa          | APHA 9213 E (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Total Bacterial Count           | APHA 9215 B (23rd Edition)   | CFU/ml     | 10@37°C    | <1      |
| Total Coliforms                 | APHA 9222 B (23rd Edition)   | CFU/100 ml | Zero       | Zero    |
| Remarks                         | The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |            |            |         |

|          |   |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable |
|----------|---|

|   |         |
|---|---------|
| Test method deviation   | None    |
| Test performed by Emp#  | 74 & 78 |
| Report prepared by Emp#   | 22      |
| The above test results are only applicable to the sample(s) referred above. |         |

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**