

## TEST REPORT

Report No: QMTL/R-100582/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100582	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A1- Building Level Ground, Drinking Fountain- (NYUAD:00064663)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 10:00 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

  
**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100583/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100583	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A1- Building Level 1, Drinking Fountain- (NYUAD:00088832)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 10:10 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	20.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100590/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100590	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A2 Building Ground Level, Drinking Fountain-(NYUAD:00086450)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 11:20 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100591/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100591	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A2 Building Level-01, Drinking Fountain-(NYUAD:00088865)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 11:30 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	21.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100592/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100592	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A3 Building Ground Level, Drinking Fountain-(NYUAD:00088969)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 11:40 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100593 Rev 01/2020

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN: MR. JASMAN PINTO</b>	Sample ID	QMTL/S-100593	
	Date Received	13 Apr 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	22 Apr 2020	
Sample Description	<b>A3 Building Level-1 Drinking Fountain – (NYUAD 00088741)</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/11:50 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample On-site Temp	22.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>rd</sup> EDITION)	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Escherichia coli	APHA 9222 H & I (23 <sup>rd</sup> EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 <sup>rd</sup> EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 <sup>rd</sup> EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 <sup>rd</sup> EDITION))	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23 <sup>rd</sup> EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 <sup>th</sup> Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-100593 reported on 21 Apr 2020.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-100604/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100604	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A4 Building Ground Level, Drinking Fountain-(NYUAD:00119015)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 1:40 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100605/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100605	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A4 Building Level 01, Drinking Fountain-(NYUAD:00119054)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 1:50 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100606/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100606	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A5 Building Level 01, Drinking Fountain-(NYUAD:00087350)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 2:00 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	21.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100607/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100607	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A5 Building Ground Level, Drinking Fountain-(NYUAD:00049075)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 2:10 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100608/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100608	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A6 Building Level 01, Drinking Fountain-(NYUAD:00084536)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 2:20 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100609/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100609	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	A6 Building Ground Level, Drinking Fountain-(NYUAD:00087230)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 2:30 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100586/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100586	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C1-Building Ground Level Drinking Fountain (NYUAD:00119633)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 10:40 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100587/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100587	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C1-Building Level 01, Drinking Fountain(NYUAD : 00135524)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 10:50 AM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100594/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100594	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C2 Building Ground Level, Drinking Fountain-(NYUAD:00104738)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 12:00 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100596/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100596	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C2 Building Level 01, Drinking Fountain-(NYUAD:00077407)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 12:20 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	20°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100599/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100599	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C2 Building Level 02, Drinking Fountain-(NYUAD:00077434)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 12:50 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100601/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100601	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C2 Building Level 03, Drinking Fountain-(NYUAD:00119472)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 1:10 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100614/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100614	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C3 Building Gound Level, Drinking Fountain-(NYUAD:00114807)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 2:55 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-100615/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-100615	
	Date Received	13 Mar 2020	
	Date(s) Tested	13 Apr 2020 - 15 Apr 2020	
	Date Reported	21 Apr 2020	
Sample Description	C3 Building Level 01, Drinking Fountain-(NYUAD:00113090)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	13.04.2020/ 3:00 PM
Sample Container	1x500ML PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.5°C	Sample Onsite Temp	22.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided. NA : Not Available			
Test method deviation	None			
Test performed by Emp#	74 & 78			
Report prepared by Emp#	72			
The above test results are only applicable to the sample(s) referred above.				

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**