

TEST REPORT

Report No: QMTL/R-92898/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92898
	Date Received	10 Feb 2020
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020
	Date Reported	20 Feb 2020
Sample Description	A1 Building, Drinking Fountain Ground Level NYUAD:00064663	
Sample Type	Water	Sampling Method QMTL-WI-15
Client Name/Project	NP	Sampled By QMTL Representative
Location	AUH	Sampling Date/Time 10.02.2020/3:50 PM
Sample Container	1x500mL PB	Sampling Point Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp 21.8°C
Sample Appearance	Clear	On-site Treatment NP
Reference	NYUAD	

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92899/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92899	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A1 Building, Drinking Fountain Level 01, NYUAD: 00088832		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/4:00 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	21.6°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92896/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92896	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A2 Building, Drinking Fountain Ground Level, NYUAD:00086451		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/3:35 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	21.2°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92897/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92897	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A2 Building, Drinking Fountain Ground Level 01, NYUAD:00088865		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/3:45 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	21.4°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92894/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92894	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A3 Building, Drinking Fountain Level Ground , NYUAD:00088970		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/3:15 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	19.5°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92895/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92895	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A3 Building, Drinking Fountain Level 01, NYUAD:00088740		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/3:20 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	19.6°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92892/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92892	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A4 Building, Drinking Fountain Level Ground, NYUAD:00119014		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/2:55 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92893/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92893	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A4 Building, Drinking Fountain Level 01, NYUAD:00119055		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/3:05 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	19.1°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92887/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92887	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A5 Building, Drinking Fountain Level Ground , NYUAD:00049074		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/2:16 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	18.4°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92888/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-92888	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	ATTN : MR. JASMAN PINTO	Date Reported	20 Feb 2020
Sample Description	A5 Building, Drinking Fountain Level 01 , NYUAD:00087350		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/2:20 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	18.5°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92889/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92889	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A6 Building, Drinking Fountain Level Ground , NYUAD:00087224		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/2:30 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	18.9°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-92890/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-92890	
	Date Received	10 Feb 2020	
	Date(s) Tested	10 Feb 2020 - 12 Feb 2020	
	Date Reported	20 Feb 2020	
Sample Description	A6 Building, Drinking Fountain Level 01 , NYUAD:00084536		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	10.02.2020/2:35 PM
Sample Container	1x500mL PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	18.9°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93056/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-93056	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
Sample Description	C1 Building, Ground Level, Drinking Fountain, NYUAD 00119632		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/02:38 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93057/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-93057	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
Sample Description	C1 Building, Level 01, Drinking Fountain, NYUAD 00135525		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/03:00 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93044/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93044	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C2 Building, Drinking Fountain, NYUAD 00104738, Ground Level		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/10:39 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable
----------	---

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93048/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93048	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C2 Building, Level 01, Drinking Fountain, NYUAD 00077408		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/12:00 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93049/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93049	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C2 Building, Drinking Fountain, Level 02, NYUAD 00077435		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/12:18 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93052/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93052	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C2 Building, Level 03, Drinking Fountain, NYUAD 00119473		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/01:05 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	20.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93042/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93042	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	Date Reported	24 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C3 Building, Level Ground, Drinking Fountain NYUAD 00114808		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/10:10 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	18.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Working Instruction, NP: Not Provided, NA: Not Applicable
----------	---

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-93043/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-93043	
	Date Received	11 Feb 2020	
	Date(s) Tested	11 Feb 2020 - 13 Feb 2020	
	ATTN : MR. JASMAN PINTO	Date Reported	24 Feb 2020
Sample Description	C3 Building ,Level - 01, Drinking Fountain NYUAD 00113091		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	11.02.2020/10:25 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	5°C	Sample Onsite Temp	18.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NYUAD		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT