

**TEST REPORT**

REPORT NO:-QMTL/R-80996

|   |                                 |   |
|---|---------------------------------|---|
| <b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b><br>P.O.Box.131463, Abu Dhabi, U.A.E<br>Ph:02-6508930/0557167017 |                                 |   |
| <b>ATTN:Mr. JASMAN PINTO</b>  |                                 |   |
| Product: Water  | Sampling Method: APHA 9060 A    | Sample ID: QMTL/S-80996                       |
| Reference: ADIA - HQ  | Sampled By: QMTL Representative | Date Received: 20.11.2019                     |
| <b>Sample Description:</b><br>HQ, Water Fountain<br>Sample Onsite Temp: 26°C<br>Sample Receipt Temp: 4°C          | Source: Fountain                | Date(s) Tested: 20-22.11.2019                 |
|   | Sample Container: 1x500 ml PB   | Date Reported: 26.11.2019                     |
|   | Sample Appearance: Clear        | Date of Sampling/Time:<br>20.11.2019/09.50 PM |
| On-Site Treatment: NA   | Tested by Emp#: 55 & 74         | Location: AUH                                 |

**TEST RESULTS**

| PARAMETERS                      | TEST METHODS<br>(APHA 23 <sup>RD</sup> EDITION) | UNITS     | SPECIFICATIONS | RESULTS     |
|---------------------------------|---|-----------|----------------|-------------|
| <b>MICROBIOLOGICAL ANALYSIS</b> |   |           |                |             |
| Total Bacterial Count           | APHA 9215 B                                     | CFU/ml    | 500            | <1          |
| Total Coliforms                 | APHA 9222 B                                     | CFU/100ml | -              | <b>Zero</b> |
| Faecal coliform                 | APHA 9222 D                                     | CFU/100ml | -              | <b>Zero</b> |
| Pseudomonas aeruginosa          | APHA 9213 E                                     | CFU/100ml | -              | <b>Zero</b> |
| Escherichia coli                | APHA 9222 H & I                                 | CFU/100ml | -              | <b>Zero</b> |

REMARKS: The sample meets DM Water Systems quality 2010 specifications for Fountain Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 72

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**