

TEST REPORT

REPORT NO: - QMTL/R-80363

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80363
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-1, Potable Water Tanks Sample Onsite Temp: 30°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80391

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80391
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-1, Potable Water Tanks Sample Onsite Temp: 30°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO: - QMTL/R-80364

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80364
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-2, Potable Water Tanks Sample Onsite Temp: 29.5°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80392

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80392
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-2, Potable Water Tanks Sample Onsite Temp: 29.5°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO: - QMTL/R-80365

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80365
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-3, Potable Water Tanks Sample Onsite Temp: 24°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80393

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80393
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-3, Potable Water Tanks Sample Onsite Temp: 24°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80366

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80366
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-4, Potable Water Tanks Sample Onsite Temp: 26°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.
END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80394

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80394
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-4, Potable Water Tanks Sample Onsite Temp: 26°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80367

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80367
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-5, Potable Water Tanks Sample Onsite Temp: 30°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80395

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80395
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-5, Potable Water Tanks Sample Onsite Temp: 30°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced, (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80368

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80368
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-6, Potable Water Tanks Sample Onsite Temp: 20°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.
END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80396

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80396
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-6, Potable Water Tanks Sample Onsite Temp: 20°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80369

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80369
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-7, Potable Water Tanks Sample Onsite Temp: 24°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.
END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80397

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80397
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-7, Potable Water Tanks Sample Onsite Temp: 24°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80370

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80370
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-8, Potable Water Tanks Sample Onsite Temp: 16.1°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	10
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80398

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80398
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-8, Potable Water Tanks Sample Onsite Temp: 16.1°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO: - QMTL/R-80371

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80371
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-9, Potable Water Tanks Sample Onsite Temp: 26°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80399

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80399
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-9, Potable Water Tanks Sample Onsite Temp: 26°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO: - QMTL/R-80372

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S- 80372
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 17.11.2019
Sample Description: P2- Water Tank-10, Potable Water Tanks Sample Onsite Temp: 28°C Sample Receipt Temp: 4°C	Source: Valve	Date(s) Tested: 17-19.11.2019
	Sample Container: 1x500 ml PB	Date Reported: 23.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	10
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health – Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NA : Not Applicable

Report prepared by Emp#: 61
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-80400

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 80400
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received : 17.11.2019
Sample Description: P2- Water Tank-10, Potable Water Tanks Sample Onsite Temp: 28°C Sample Receipt Temp: 19°C	Source: Valve	Date(s) Tested : 17-27.11.2019
	Sample Container: 1X1L PB	Date Reported : 06.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 17.11.2019/04:30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS : The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, HAAD: The Health Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT