

TEST REPORT

REPORT NO:-QMTL/R-84600

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84600
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Basement Clinic- Cold Water Sample Onsite Temp: 24.6°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.30 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84601

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84601
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Basement Shower Room- Cold Water Sample Onsite Temp: 26°C Sample Receipt Temp: 4°C	Source: Shower	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.37 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84606

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84606
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Mezzanine Floor- Kitchen- Cold Water Sample Onsite Temp: 24.4°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.14 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84608

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84608
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 16 th Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 23°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.17 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84610

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84610
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 16 th Floor Wing B, Pantry- Cold Water Sample Onsite Temp: 22.8°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.27 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84613

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84613
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 31 st Floor Wing B, Pantry- Cold Water Sample Onsite Temp: 26°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.43 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84615

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84615
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 32 nd Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 26.1°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/12.47 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84616

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84616
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 33 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 26.2°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.10 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84617

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84617
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 34 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 25.9°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.33 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84618

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84618
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 35 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 25.1°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.52 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84619

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84619
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 36 th Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 24.3°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/02.11 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84620

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84620
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 36 th Floor Shower Room- Cold Water Sample Onsite Temp: 25°C Sample Receipt Temp: 4°C	Source: Shower	Date(s) Tested: 14-16.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 21.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/02.46 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84622

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84622
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Basement Clinic- Cold Water Sample Onsite Temp: 24.6°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.30 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84623

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84623
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Basement Shower Room- Cold Water Sample Onsite Temp: 26°C Sample Receipt Temp: 16°C	Source: Shower	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/10.37 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84628

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84628
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : Mezzanine Floor- Kitchen- Cold Water Sample Onsite Temp: 24.4°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.14 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84630

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84630
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 16 th Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 23° Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.17 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84632

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84632
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 16 th Floor Wing B, Pantry- Cold Water Sample Onsite Temp: 22.8°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.27 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84635

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84635
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 31 st Floor Wing B, Pantry- Cold Water Sample Onsite Temp: 26°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/11.43 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84637

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84637
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 32 nd Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 26.1°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/12.47 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84638

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84638
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 33 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 26.2°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.10 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84639

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84639
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 34 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 25.9°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.33 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84640

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84640
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 35 Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 25.1°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/01.52 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84641

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84641
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 36 th Floor Wing A, Pantry- Cold Water Sample Onsite Temp: 24.3°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/02.11 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84642

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84642
Reference: ADIA – HEAD QUARTERS	Sampled By: QMTL Representative	Date Received: 14.12.2019
Sample Description : 36 th Floor Shower Room- Cold Water Sample Onsite Temp: 25°C Sample Receipt Temp: 16°C	Source: Shower	Date(s) Tested: 14-24.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.12.2019/02.46 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84720

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84720
Reference: ADIA – CAR PARKING	Sampled By: QMTL Representative	Date Received: 15.12.2019
Sample Description : Basement 03, Mess Hall- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 15-17.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 15.12.2019/10.44 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84730

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-84730
Reference: ADIA – CAR PARKING	Sampled By: QMTL Representative	Date Received: 15.12.2019
Sample Description : 01 st Floor Driver Room- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 4°C	Source: Tap	Date(s) Tested: 15-17.12.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 15.12.2019/01.05 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84743

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84743
Reference: ADIA – CAR PARKING	Sampled By: QMTL Representative	Date Received: 15.12.2019
Sample Description : Basement 03, Mess Hall- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 15-25.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 15.12.2019/10.44 AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-84753

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84753
Reference: ADIA – CAR PARKING	Sampled By: QMTL Representative	Date Received: 15.12.2019
Sample Description : 01 st Floor Driver Room- Cold Water Sample Onsite Temp: 24°C Sample Receipt Temp: 16°C	Source: Tap	Date(s) Tested: 15-25.12.2019
	Sample Container: 1x1 L PB	Date Reported: 28.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 15.12.2019/01.05 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	Basement - Clinic

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.21
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	219
3	Total Dissolved Solids (TDS)	Max 1000	142
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.17
7	Calcium Hardness at 25°C	200	57
8	Total Hardness at 25°C	300	62

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	33
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	Basement Shower Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.31
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	214
3	Total Dissolved Solids (TDS)	Max 1000	139
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.16
7	Calcium Hardness at 25°C	200	54
8	Total Hardness at 25°C	300	61

Inorganic Chemical Parameter

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	31
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	HQ Mezzanine Floor-Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.09
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	227
3	Total Dissolved Solids (TDS)	Max 1000	147
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.11
7	Calcium Hardness at 25°C	200	53
8	Total Hardness at 25°C	300	60

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	37
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	Wing 16 A Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.13
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	221
3	Total Dissolved Solids (TDS)	Max 1000	143
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.15
7	Calcium Hardness at 25°C	200	53
8	Total Hardness at 25°C	300	59

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	31
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj

Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	Wing 16 B Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.17
2	Conductivity at 25°C, µs/cm	----	205
3	Total Dissolved Solids (TDS)	Max 1000	133
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 – 0.5	0.13
7	Calcium Hardness at 25°C	200	56
8	Total Hardness at 25°C	300	62

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	30
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	Wing 31 B Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.06
2	Conductivity at 25°C, µs/cm	----	211
3	Total Dissolved Solids (TDS)	Max 1000	137
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 – 0.5	0.16
7	Calcium Hardness at 25°C	200	50
8	Total Hardness at 25°C	300	57

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	36
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	L 36 Shower Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.16
2	Conductivity at 25°C, µs/cm	----	218
3	Total Dissolved Solids (TDS)	Max 1000	143
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.15
7	Calcium Hardness at 25°C	200	49
8	Total Hardness at 25°C	300	55

Inorganic Chemical Parameters


1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	32
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	14-12-2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Cold Outlet)	Sample Point	L 36 Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	7.91
2	Conductivity at 25°C, µs/cm	----	235
3	Total Dissolved Solids (TDS)	Max 1000	152
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.14
7	Calcium Hardness at 25°C	200	51
8	Total Hardness at 25°C	300	56

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	33
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	15-12-2019
Sampled By	Crystalline Rep	Location	ADIA - CAR PARKING
Sample Type	Potable Water (Cold Outlet)	Sample Point	B3 - Mess Hall

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.23
2	Conductivity at 25°C, µs/cm	----	234
3	Total Dissolved Solids (TDS)	Max 1000	152
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.11
7	Calcium Hardness at 25°C	200	53
8	Total Hardness at 25°C	300	62

Inorganic Chemical Parameters


1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	37
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer



POTABLE WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	15-12-2019
Sampled By	Crystalline Rep	Location	ADIA - CAR PARKING
Sample Type	Potable Water (Cold Outlet)	Sample Point	L1- Driver Shower Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.11
2	Conductivity at 25°C, µs/cm	----	205
3	Total Dissolved Solids (TDS)	Max 1000	133
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.11
7	Calcium Hardness at 25°C	200	42
8	Total Hardness at 25°C	300	53

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	30
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,
Murugaraaj
Murugaraaj
Service Engineer

