

TEST REPORT

REPORT NO:-QMTL/R-76070

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-76070
Reference: HEALTHPOINT HOSPITAL	Sampled By: QMTL Representative	Date Received: 14.10.2019
Sample Description : Hydrotherapy Sample Onsite Temp: 31.4°C Sample Receipt Temp: 20°C	Source: Pool	Date(s) Tested: 14-24.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 14.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation: None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016