

## TEST REPORT

Report No: QMTL/R-91878/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-91878	
	Date Received	04 Feb 2020	
	Date(s) Tested	04 Feb 2020 - 14 Feb 2020	
	Date Reported	26 Feb 2020	
Sample Description	Level 1 GRP Tank No:2		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	AUH	Sampling Date/Time	NP
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	29°C	Sample Onsite Temp	27°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	AL MARIAH TOWER		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5th Edition)	cfu/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-91879/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-91879	
	Date Received	04 Feb 2020	
	Date(s) Tested	04 Feb 2020 - 14 Feb 2020	
	Date Reported	26 Feb 2020	
Sample Description	Level 24, GRP Tank No:5		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	AUH	Sampling Date/Time	NP
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	29°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	AL MARIAH TOWER		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5th Edition)	cfu/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-91876 /2020

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	<b>QMTL/S-91876</b>
		Date Received	<b>04 Feb 2020</b>
		Date(s) Tested	<b>04 Feb 2020-06 Feb 2020</b>
		Date Reported	<b>08 Feb 2020</b>
<b>ATTN: Mr. JASMAN PINTO</b>			
Sample Description	Level 1, GRP Tank No2		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	AUH	Sampling Date/Time	NP
Sample Container	1x500mL PB	Sampling Point	Tank
Sample Receipt Temp	29°C	Sample On-site Temp	27°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	<b>AI MARIAH TOWER</b>		

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>rd</sup> EDITION)	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS OF WATER</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>9</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

Remarks	The sample meets RSB Water Quality Regulations (4 <sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, APHA: American Public Health Association
Test Method Deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	14
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-91877/2020

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-91877
		Date Received	04 Feb 2020
		Date(s) Tested	04 Feb 2020-06 Feb 2020
		Date Reported	08 Feb 2020
<b>ATTN: Mr. JASMAN PINTO</b>			
Sample Description	Level 24, GRP Tank No5		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	AUH	Sampling Date/Time	NP
Sample Container	1x500mL PB	Sampling Point	Tank
Sample Receipt Temp	29°C	Sample On-site Temp	26°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	AI MARIAH TOWER		

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>rd</sup> EDITION)	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS OF WATER</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>9</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

Remarks	The sample meets RSB Water Quality Regulations (4 <sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, APHA: American Public Health Association
Test Method Deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	14
The above test results are only applicable to the sample(s) referred above.	

### Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**