



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2009-18979



Request No. : WA-Q-L-2009-02870

Sample No. : WA-S-L-2009-18250

Sampling Date	: 06/09/2020	Report Date.	: 09/09/2020
Analysis Start Date.	: 06/09/2020	Analysis End Date.	: 09/09/2020
Sample Location.	: Al Noor Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Main Pool
Sampling Point	: Not Applicable	Preservation	: Not Applicable
Sample Description	: Pool Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool), Issued by the head of urban planning and municipalities No.(3) for the year 2018, Page No.3.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	AL NOOR TOWER	Visit Date:	06-09-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.58
2	Conductivity at 25°C, µs/cm	---	415
3	TDS, ppm	Max 1500	269
4	Alkalinity	80 - 120	88
5	Calcium Hardness	200 - 500	206
6	Residual Chlorine	1.0 - 3.0	1.09
7	Cyanuric Acid	20 - 60	28
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,

Muruganaj
Service Engineer

