

## TEST REPORT

Report No: QMTL/R-96887/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-96887</td> </tr> <tr> <td>Date Received</td> <td>09 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>09 Mar 2020 - 11 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>18 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-96887	Date Received	09 Mar 2020	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	Date Reported	18 Mar 2020
Sample ID	QMTL/S-96887								
Date Received	09 Mar 2020								
Date(s) Tested	09 Mar 2020 - 11 Mar 2020								
Date Reported	18 Mar 2020								
Sample Description	<b>A6 Building Ground Floor Banquet Kitchen</b>								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	09.03.2020/11:30 AM						
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap						
Sample Receipt Temp	4.7°C	Sample Onsite Temp	25°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	78 & 74 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-97035/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97035
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	D1 Building Kitchen, Food Preparation Area		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/11:30 AM
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97032/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97032	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	18 Mar 2020	
Sample Description	<b>C1 Building - Ground Level - ERB Kitchen, Food Preparation Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:20 AM
Sample Container	1x500ml PB	Sampling Point	Tap(Sink)
Sample Receipt Temp	4.2°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-97031/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97031
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>C1 Building - Ground Floor - ERB kitchen, Serving Area, Hand Wash</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:10 AM
Sample Container	1x500ml PB	Sampling Point	Hand Wash Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	23.0°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-97039/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97039
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C2- Building- Ground Floor, Health & Wellness Center - Pantry		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/01:15 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97038/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97038
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	18 Mar 2020
Sample Description	<b>C2 Building, Health &amp; Wellness Center - Wash Room</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/12:30 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97040/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Sample ID</td> <td>QMTL/S-97040</td> </tr> <tr> <td>Date Received</td> <td>10 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>10 Mar 2020 - 12 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>18 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-97040	Date Received	10 Mar 2020	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	Date Reported	18 Mar 2020
Sample ID	QMTL/S-97040								
Date Received	10 Mar 2020								
Date(s) Tested	10 Mar 2020 - 12 Mar 2020								
Date Reported	18 Mar 2020								
Sample Description	<b>C2 Building - Level 01 - Convenience Store</b>								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	10.03.2020/01:30 PM						
Sample Container	1x500ml PB	Sampling Point	Tap						
Sample Receipt Temp	4.2°C	Sample Onsite Temp	24.6°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97042/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97042
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>C2 Building - Level 2 - SMP Kitchen Food Preparation Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:00 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	24°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97043/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97043
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>C2 Building - Level 2 - EL Fuego Kitchen, Hand Wash</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:15 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97045/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97045
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C2 Building - Level 03 - Library Cafe		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:40 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
  
**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97036/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97036
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>D1 Building Kitchen, The Grill Kitchen, Hand Wash</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/11:40 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4.2°C	Sample Onsite Temp	26.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96879/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96879
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>D2 Kitchen Food Preservation Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:40 AM
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	4.7°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	78 & 74 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-96880/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96880
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>D2 Kitchen The Grill Kitchen Hand Wash</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:45 AM
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	4.7°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	78 & 74 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96881/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-96881
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>D2 Level 01 Touch Club Food Preparation Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:50 AM
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	4.7°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	78 & 74 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96882/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-96882
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	<b>D2 Level 01 Touch Club Serving Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:10 AM
Sample Container	1x500ml PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	4.7°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	78 & 74 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96657/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-96657</td> </tr> <tr> <td>Date Received</td> <td>08 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>08 Mar 2020 - 10 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>16 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-96657	Date Received	08 Mar 2020	Date(s) Tested	08 Mar 2020 - 10 Mar 2020	Date Reported	16 Mar 2020
Sample ID	QMTL/S-96657								
Date Received	08 Mar 2020								
Date(s) Tested	08 Mar 2020 - 10 Mar 2020								
Date Reported	16 Mar 2020								
Sample Description	<b>B2 Building, Day Care - Center, Kitchen</b>								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	08-03-2020 / 09.40AM						
Sample Container	1x500ml PB	Sampling Point	Tap						
Sample Receipt Temp	4°C	Sample Onsite Temp	22°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-96922/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96922
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	22 Mar 2020
Sample Description	<b>A6 Building Ground Floor Banquet Kitchen</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/11:20 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55, 74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96683/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96683
ATTN : MR. JASMAN PINTO		Date Received	08 Mar 2020
		Date(s) Tested	08 Mar 2020 - 18 Mar 2020
		Date Reported	19 Mar 2020
Sample Description	B2 Building, Day Care Center, Kitchen		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	08-03-2020 / 09.40 AM
Sample Container	2x500ml PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97047/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97047	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C1 Building-Ground Floor - ERB Kitchen, Serving Area, Hand Wash		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:10 AM
Sample Container	1x1L PB	Sampling Point	Hand Wash Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97048/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97048	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C1 Building-Ground Level-ERB kitchen, Food Preparation Area		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:20 AM
Sample Container	1x1L PB	Sampling Point	Tap(Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97055/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97055	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 - Building- Ground Floor, Health & Wellness Center- Pantry		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/01:15 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97054/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97054	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 Building, Health & Wellness Center - Wash Room		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/12:30 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97056/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97056	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 Building - Level 01- Convenience Store		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/01:30 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	24.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97058/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97058	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 Building - Level 2 - SMP Kitchen Food Preparation Area		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:00 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	24°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar			
Test method deviation	None			
Test performed by Emp#	74 & 55			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97059/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97059	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 Building- Level 2- EL Fuego Kitchen, Hand Wash		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:15 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97061/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97061	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2 Building - Level 03- Library Cafe		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:40 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97051/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97051	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	D1 Building Kitchen, Food Preparation Area		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/11:30 AM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97052/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-97052	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	D1 Building Kitchen, The Grill Kitchen, Hand Wash		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/11:40 AM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	26.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96914/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96914
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	D2 Kitchen, Food Preparation Area		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:40 AM
Sample Container	1x1L PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-96915/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96915
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	D2 Kitchen, The Grill Kitchen Hand Wash		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:45 AM
Sample Container	1x1L PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-96916/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-96916
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	<b>D2, Level 01 Touch Club Food Preparation Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/9:50 AM
Sample Container	1x1L PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-96917/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-96917	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	<b>D2, Level 01, Touch Club Serving Area</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:10 AM
Sample Container	1x1L PB	Sampling Point	Kitchen Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**