TEST REPORT

Report No: QMTL/R-122410/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122410
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building A6 Ground Level, Banquet Wash Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 10:05 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122413/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122413
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building C1, Ground Level, ERB Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 10:55 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	26.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122414/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122414
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building C1, Level - 1 , ERB Kitchen, Serving Area Handwash**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 11:15 AM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	29.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122437/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122437
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D1, Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 04:35 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122438/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122438
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D1, Kitchen Globel**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 04:40 PM
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	21°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122406/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122406
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D2, Ground Level, Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:00 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122407/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122407
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D2, The Meal Club**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:12 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	27.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122408/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122408
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D2, Level 1, Torch Club Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:25 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122409/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122409
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 24 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	27 Sep 2020

Sample Description	**Building D2, Level 1, Torch Club Serving Area**		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:40 AM
Sample Container	1x1L PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	21°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pnuemophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnuemophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122375/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122375
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building A6 Ground Level, Banquet Wash Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 10:10 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122378/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122378
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building C1, Ground Level, ERB Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 11:00 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	26.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122379/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122379
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building C1, Level - 1 , ERB Kitchen, Serving Area Handwash**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 11:20 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	29.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122402/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122402
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building D1, Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 04:38 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122403/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122403
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building D1, Kitchen Globel**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 04:43 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122371/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**		Sample ID	QMTL/S-122371
		Date Received	14 Sep 2020
		Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO		Date Reported	23 Sep 2020

Sample Description	**Building D2, Ground Level, Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:08 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122372/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122372
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building D2, The Meal Club**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:15 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	27.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122373/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122373
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building D2, Level 1, Torch Club Kitchen, Food Preparation Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:30 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

مختبر كولنياس الكيميائي QUALITAS MATERIAL TESTING LABORATORIES

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com

TEST REPORT

Report No: QMTL/R-122374/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES **Abu Dhabi PO Box : 131463** **United Arab Emirates**	Sample ID	QMTL/S-122374
	Date Received	14 Sep 2020
	Date(s) Tested	14 Sep 2020 - 16 Sep 2020
ATTN : MR. JASMAN PINTO	Date Reported	23 Sep 2020

Sample Description	**Building D2, Level 1, Torch Club Serving Area**		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD, Abu Dhabi	Sampling Date/Time	14.09.2020 / 09:45 AM
Sample Container	1x500ml PB	Sampling Point	Tap (Sink)
Sample Receipt Temp	4°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

P.O. Box: 9035, M-15, Plot No. 21, Block C Store 5, 7&8, Mussafah
Abu Dhabi, U.A.E Tel.: +971 2 5552928 Fax: +971 2 5552927
E-mail: info@qualitasme.com
Website: www.qualitasme.com