



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2006-0183

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9928
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 19/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 18/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: RCC Tank 1
Sampling Point	: Basement	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H&I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= $\leq$ 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.





مختبرات ويمبي ذم م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

**Microbiology Test Report**

Report No. : WA-R-L-2006-0183

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2006-0182

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9928
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 26/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 25/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: RCC Tank 1
Sampling Point	: Basement	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2006-0179

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9926
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 19/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 18/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: GRP Tank 1
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= $\leq$ 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

**Microbiology Test Report**

Report No. : WA-R-L-2006-0179

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2006-0178

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9926
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 26/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 25/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: GRP Tank 1
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2006-0181

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9927
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 19/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 18/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: GRP Tank 2
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= $\leq$ 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.





**Microbiology Test Report**

Report No. : WA-R-L-2006-0181

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2006-0180

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-1606	Sample No.	: WA-S-L-2006-9927
Sampling Date/time	: 15/4/2020 , 11:57	Report Date.	: 26/4/2020
Analysis Start Date.	: 15/4/2020	Analysis End Date.	: 25/4/2020
Sample Location.	: Al Nahel Tower	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: GRP Tank 2
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -