



**Microbiology Test Report**

**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-L-2006-01765

Sampling Date/time : 16/6/2020 , 19:10

Analysis Start Date. : 16/6/2020

Sample Location. : ADIA, Car Parking, Abu Dhabi

Sample Identification : EM:44880, CP-05M-PLM-WTF-Tank 5

Sample Certificate No : 0844

Temperature °C : 31.9°C

Sampling Container : Sterile Plastic Bottle

Sampling Point : Pool

Sample Description : Swimming Pool Water

Sample No. : WA-S-L-2006-10912

Report Date. : 20/6/2020

Analysis End Date. : 19/6/2020

Sampled By : Shoukth

Sample Submitted as : Water

Sampling Method : APHA 9060 A&B

Site Observation : Clear

Source of Sample : 5th Floor Swimming  
Pool Plant Room  
Swimming Pool  
Balancing Water Tank

Preservation : 4-8°C

Report No. WA-R-L-2006-11177



Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool),

Issued by the head of urban planning and municipalities No.(3) for the year 2018, Page No.3.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2006-11177

Signed for and on behalf of Wimpey Laboratories



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2006-11196

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463  
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:  
971 265 8942



Request No.	: WA-Q-L-2006-01765	Sample No.	: WA-S-L-2006-10932
Sampling Date	: 16/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 16/6/2020	Analysis End Date.	: 26/6/2020
Sample Location.	: ADIA, Car Parking, Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0844	Sampling Method	: BS 7592
Temperature °C	: 31.9°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: 5th Floor Swimming Pool Plant Room Swimming Pool Balancing Water Tank
Sampling Point	: Pool	Preservation	: 10°C
Sample Description	: Swimming Pool Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limit.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**  
Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -