



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7010

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6850
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: APHA 9060 A&B
Temperature °C	: 29.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Male Prayer Room
Sampling Point	: P1, Tap Water	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU


Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7070



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6911
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: BS 7592
Temperature °C	: 29.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Male Prayer Room
Sampling Point	: P1, Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7003



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6843
Sampling Date/time	: 12/4/2020 , 14:30	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi)	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0375	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Tank
Sampling Point	: Irrigation Pump Room, P3-Tower A	Preservation	: 4-8°C
Sample Description	: Irrigation Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	23CFU/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	900	--
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	--
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	10	--

Note : Not Detected= \leq 10CFU/100ml

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the available specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2004-7003

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7056



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6900
Sampling Date/time	: 12/4/2020 , 14:30	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi)	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0375	Sampling Method	: BS 7592
Temperature °C	: 22.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Tank
Sampling Point	: Irrigation Pump Room, P3-Tower A	Preservation	: 10°C
Sample Description	: Irrigation Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU OR MPN/ml

Note : Limit of Detection=<10CFU/ml

Procedure: WSOR-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.


Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7008



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6848
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: APHA 9060 A&B
Temperature °C	: 30.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1
Sampling Point	: P3, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	30	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7068



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6909
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: BS 7592
Temperature °C	: 30.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1
Sampling Point	: P3, Pump Room	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7009

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6849
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: APHA 9060 A&B
Temperature °C	: 28.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: P3, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU


Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7069



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6910
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: BS 7592
Temperature °C	: 28.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: P3, Pump Room	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7006

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6846
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: APHA 9060 A&B
Temperature °C	: 30.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1, Pump Room
Sampling Point	: Level - 31	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7060



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6904
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: BS 7592
Temperature °C	: 30.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1, Pump Room
Sampling Point	: Level - 31	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7007



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6847
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: APHA 9060 A&B
Temperature °C	: 31.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2, Pump Room
Sampling Point	: Level - 31	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7061



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6905
Sampling Date/time	: 12/4/2020 , 13:50	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower A	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0376	Sampling Method	: BS 7592
Temperature °C	: 31.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2, Pump Room
Sampling Point	: Level - 31	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7004



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6844
Sampling Date/time	: 12/4/2020 , 14:30	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi)	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0375	Sampling Method	: APHA 9060 A&B
Temperature °C	: 26.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Tank
Sampling Point	: Irrigation Pump Room, Wash Room Tower A	Preservation	: 4-8°C
Sample Description	: Irrigation Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	23CFU/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	600	--
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	--
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	12	--

Note : Not Detected=<10CFU/100ml

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2004-7004

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7058



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6902
Sampling Date/time	: 12/4/2020 , 14:30	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi)	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0375	Sampling Method	: BS 7592
Temperature °C	: 26.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Tank
Sampling Point	: Irrigation Pump Room, Wash Room Tower A I	Preservation	: 10°C
Sample Description	: Irrigation Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU OR MPN/ml

Note : Limit of Detection= <10 CFU/ml

Procedure: WSOP-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist



Test results relate only to the samples tested.
This report shall not be reproduced except in full, without the written approval of the Laboratory.
This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -