



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7013

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6857
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: APHA 9060 A&B
Temperature °C	: 29.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1
Sampling Point	: P3, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	40	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7014



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6858
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: APHA 9060 A&B
Temperature °C	: 30.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: P3, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2004-7074

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6915
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: BS 7592
Temperature °C	: 30.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: P3, Pump Room	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.


Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7011

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6855
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: APHA 9060 A&B
Temperature °C	: 31.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1
Sampling Point	: Level - 27, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2004-7071

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6912
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: BS 7592
Temperature °C	: 31.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 1
Sampling Point	: Level - 27, Pump Room	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7012

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6856
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: APHA 9060 A&B
Temperature °C	: 28.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: Level - 27, Pump Room	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7072



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6913
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: BS 7592
Temperature °C	: 28.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Tank - 2
Sampling Point	: Level - 27, Pump Room	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.


Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2004-7015

Crystalline Environmental Services



Request No.	: WA-Q-L-2004-1133	Sample No.	: WA-S-L-2004-6859
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 15/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 14/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: APHA 9060 A&B
Temperature °C	: 28.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Male Wash Room
Sampling Point	: Wash Basin, Tap Water P1	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU


Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2004-7075



Request No.	: WA-Q-L-2004-1137	Sample No.	: WA-S-L-2004-6916
Sampling Date/time	: 12/4/2020 , 14:00	Report Date.	: 22/4/2020
Analysis Start Date.	: 12/4/2020	Analysis End Date.	: 22/4/2020
Sample Location.	: Serco Middle East,(Rihan Heights Abu Dhabi) Tower B	Sampled By	: Jameel
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 0377	Sampling Method	: BS 7592
Temperature °C	: 28.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: male Wash Room
Sampling Point	: Wash Basin Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -