

TEST REPORT

Report No: QMTL/R-134434/2020

| | | | |
|---|---------------------------------|---------------------------|-----------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | Sample ID | QMTL/S-134434 | |
| | Date Received | 16 Nov 2020 | |
| | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 | |
| | Date Reported | 28 Nov 2020 | |
| Sample Description | Potable Water Tank 1 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:00 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 31.2°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |


| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134435/2020

| | | | |
|---|---------------------------------|---------------------------|-----------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | Sample ID | QMTL/S-134435 | |
| | Date Received | 16 Nov 2020 | |
| | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 | |
| | Date Reported | 28 Nov 2020 | |
| Sample Description | Potable Water Tank 2 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:10 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 32.4°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134436/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134436 |
| | | Date Received | 16 Nov 2020 |
| | | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 |
| ATTN : MR. JASMAN PINTO | | Date Reported | 28 Nov 2020 |
| Sample Description | Potable Water Tank 3 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:20 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 35.5°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134437/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | | Sample ID | QMTL/S-134437 |
| | | Date Received | 16 Nov 2020 |
| | | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 |
| | | Date Reported | 28 Nov 2020 |
| Sample Description | Potable Water Tank 4 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:30 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 35.2°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134438/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134438 |
| ATTN : MR. JASMAN PINTO | | Date Received | 16 Nov 2020 |
| | | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 |
| | | Date Reported | 28 Nov 2020 |
| Sample Description | Potable Water Tank 5 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:40 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 33.1°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134439/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134439 |
| ATTN : MR. JASMAN PINTO | | Date Received | 16 Nov 2020 |
| | | Date(s) Tested | 16 Nov 2020 - 26 Nov 2020 |
| | | Date Reported | 28 Nov 2020 |
| Sample Description | Potable Water Tank 6 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 16.11.2020 / 04:50 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 34.7°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, ISO : International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134735/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134735 |
| | | Date Received | 17 Nov 2020 |
| | | Date(s) Tested | 17 Nov 2020 - 27 Nov 2020 |
| ATTN : MR. JASMAN PINTO | | Date Reported | 30 Nov 2020 |
| Sample Description | Potable Water Tank - 7 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 17.11.2020 / 11:50 AM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 20.4°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|---|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134736/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134736 |
| ATTN : MR. JASMAN PINTO | | Date Received | 17 Nov 2020 |
| | | Date(s) Tested | 17 Nov 2020 - 27 Nov 2020 |
| | | Date Reported | 30 Nov 2020 |
| Sample Description | Potable Water Tank - 8 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 17.11.2020 / 11:55 AM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 22.6°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS


| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|---|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134737/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134737 |
| | | Date Received | 17 Nov 2020 |
| | | Date(s) Tested | 17 Nov 2020 - 27 Nov 2020 |
| ATTN : MR. JASMAN PINTO | | Date Reported | 30 Nov 2020 |
| Sample Description | Potable Water Tank - 9 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 17.11.2020 / 12:00 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 34.3°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|---|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-134738/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-134738 |
| ATTN : MR. JASMAN PINTO | | Date Received | 17 Nov 2020 |
| | | Date(s) Tested | 17 Nov 2020 - 27 Nov 2020 |
| | | Date Reported | 30 Nov 2020 |
| Sample Description | Potable Water Tank - 10 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 17.11.2020 / 12:05 PM |
| Sample Container | 1x1L PB | Sampling Point | Tank |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 33.1°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|---|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 14 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT