



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2009-19962



Request No. : WA-Q-L-2009-02967

Sample No. : WA-S-L-2009-19173

Sampling Date	: 14/09/2020	Report Date.	: 17/09/2020
Analysis Start Date.	: 14/09/2020	Analysis End Date.	: 16/09/2020
Sample Location.	: ADIA HQ, Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 2061	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35.6°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Feature
Sampling Point	: Fountain	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	500CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2009-19967



Request No. : WA-Q-L-2009-02967

Sample No. : WA-S-L-2009-19178

Sampling Date	: 14/09/2020	Report Date.	: 24/09/2020
Analysis Start Date.	: 14/09/2020	Analysis End Date.	: 24/09/2020
Sample Location.	: ADIA HQ, Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 2061	Sampling Method	: BS 7592
Temperature °C	: 35.6°C	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Water Feature
Sampling Point	: Fountain	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -