

**ENVIRONMENTAL
SERVICES FOR
A GREENER
TOMORROW...
ONE STEP AT
A TIME.**



Completion Report for

Kitchen Hood & Exhaust System Cleaning & Degreasing

Date: **20 July 2020**
Client Name: **Armed Forces Officers Club & Hotel**
Contact Person: **Ms. Shaikha Al Khaabi**
Designation: **CEO**
Site Detail: **Sheikh Abdulla Palace-Abu Dhabi**





CRYSTALLINE ENVIROMENTAL SERVICES

KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1780

CUSTOMER: SHEIKH ABULLA PALACE		CONTACT PERSON:	
SITE DETAILS: ABU DHABI		CONTACT NUMBER: 0509905305	
NAME OF KITCHEN: PALACE KITCHEN		LOCATION: G. FLOOR	
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input checked="" type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT			
Type & Size of Hood:			
Cooking Volume:	<input type="checkbox"/> Very High	<input checked="" type="checkbox"/> High	<input type="checkbox"/> Medium <input type="checkbox"/> Low
Type of Filters:	<input checked="" type="checkbox"/> Mesh	<input type="checkbox"/> Baffle	<input type="checkbox"/> N/A
Filters in Place:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Filter Cleaning Freq.	<input type="checkbox"/> Daily	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/> Monthly <input type="checkbox"/> Not Known
Comments:			
FIRE PROTECTION SYSTEM			
Kitchen:	<input checked="" type="checkbox"/> Powder	<input checked="" type="checkbox"/> CO2	<input type="checkbox"/> Foam <input type="checkbox"/> Other
Cooker Hoods:	<input checked="" type="checkbox"/> CO2	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Dry Powder <input type="checkbox"/> Other
Fire Dampers:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Fusible Links: <input type="checkbox"/> Yes <input type="checkbox"/> No
DUCTWORK			
Duct Made of:	<input checked="" type="checkbox"/> Galvanized Steel	<input type="checkbox"/> Stainless Steel	<input type="checkbox"/> Other
Physical Entry:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Access with Tools only:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Vertical Access:	<input type="checkbox"/> Rope access	<input type="checkbox"/> Safety Harness	<input checked="" type="checkbox"/> N/A
Entire System Cleaned	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No if No, give details	
Comments			
Doors/Plates Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> No. of doors <input type="checkbox"/> No of Panels
Doors/Plates Installed:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> No. of doors <input type="checkbox"/> No of Panels
Where Installed:			
Duct Size & Approx. Length:	Insulated:		<input type="checkbox"/> Yes <input type="checkbox"/> No
Condition of Ducts:	<input checked="" type="checkbox"/> Clean	<input type="checkbox"/> Dirty	<input type="checkbox"/> Very Dirty
Damaged:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Where <input type="checkbox"/> N/A
Exhaust Fans:	<input type="checkbox"/> Upblast	<input checked="" type="checkbox"/> Inline	<input type="checkbox"/> Utility <input type="checkbox"/> Others
Location:	Condition of Roof:		
LAST CLEANING DATE	CURRENT CLEANING DATE	NEXT CLEANING DATE	
	15-07-2020	15-01-2021	
CHEMICALS AND EQUIPMENTS USED			
<input checked="" type="checkbox"/> JETTING MACHINE <input checked="" type="checkbox"/> INLET WATER HOSE <input checked="" type="checkbox"/> EXTENTION CORDS <input checked="" type="checkbox"/> VACCUM CLEANER			
<input checked="" type="checkbox"/> LED LIGHTS <input checked="" type="checkbox"/> PLASTICS ROLL/BAGS <input checked="" type="checkbox"/> SUITABLE PPE <input checked="" type="checkbox"/> DEGREASER CHEMICAL <input checked="" type="checkbox"/> LADDER			
COMMENTS AND RECOMMENDATION:			
ABOVE MENTIONED KITCHEN HOOD & EXHAUST SYSTEM CLEANED			
Crystalline Representative:	HARIS	Signature: HARIS	
Customer Representative:	MO. AY. AL. WILLY	Signature: [Signature]	

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

KITCHEN HOOD CLEANING AND DEGREASING

CLIENT NAME : ARMED FORCES OFFICERS CLUB & HOTEL
CONTACT PERSON : MS. SHAIKHA AL KHAABI
DESIGNATION : CEO
SITE DETAILS : SHEIKH ABDULLA PALACE-ABU DHABI
DETAILS : KITCHEN HOOD & EXHAUST SYSTEM
CLEANING & DEGREASING
DATE OF CLEANING : 15 JULY 2020
FREQUENCY OF CLEANING : HALF YEARLY
DATE OF NEXT CLEANING : 15 JANUARY 2021

The above kitchen were cleaned in accordance with NFPA 96 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

The kitchen exhaust systems must be cleaned and degreased every Six-Monthly.



Tasman Pinto

CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES