

**ENVIRONMENTAL
SERVICES FOR
A GREENER
TOMORROW...
ONE STEP AT
A TIME.**



Completion Report for

Kitchen Hood & Exhaust System Cleaning & Degreasing

Date: **11 November 2019**
Client Name: **Armed Forces Officers Club & Hotel**
Contact Person: **Ms. Shaikha Al Khaabi**
Designation: **CEO**
Site Detail: **Al Dhafra Air Base, Al Ain Truck Road,
Abu Dhabi.**



Address: PO BOX 131463, Abu Dhabi, UAE | Phone: +971 2 650 8930, +971 55 716 7017

E-mail: info@crystalline-uae.com | Website: www.crystalline-uae.com



CRYSTALLINE ENVIROMENTAL SERVICES

KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1775

CUSTOMER: <u>AFOCH - ALDHAFRA AIRBASE</u>	CONTACT PERSON: <u>Pawan Khadka</u>
SITE DETAILS: <u>SOLDIERS KITCHEN</u>	CONTACT NUMBER: <u>0569069615</u>
NAME OF KITCHEN: <u>MAIN KITCHEN</u>	LOCATION: <u>G. FLOOR</u>
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT	

Type & Size of Hood:

Cooking Volume:	<input checked="" type="checkbox"/> Very High	<input type="checkbox"/> High	<input type="checkbox"/> Medium	<input type="checkbox"/> Low
Type of Filters:	<input checked="" type="checkbox"/> Mesh	<input type="checkbox"/> Baffle	<input type="checkbox"/> N/A	
Filters in Place:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Filter Cleaning Freq.	<input type="checkbox"/> Daily	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/> Monthly	<input type="checkbox"/> Not Known

Comments:

HOOD - 01

FIRE PROTECTION SYSTEM

Kitchen:	<input checked="" type="checkbox"/> Powder	<input type="checkbox"/> CO2	<input type="checkbox"/> Foam	<input type="checkbox"/> Other
Cooker Hoods:	<input type="checkbox"/> CO2	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Dry Powder	<input type="checkbox"/> Other
Fire Dampers:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	Fusible Links:	<input type="checkbox"/> Yes <input type="checkbox"/> No

DUCTWORK

Duct Made of:	<input type="checkbox"/> Galvanized Steel	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Other
Physical Entry:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Access with Tools only:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Vertical Access:	<input type="checkbox"/> Rope access	<input checked="" type="checkbox"/> Safety Harness	<input type="checkbox"/> N/A
Entire System Cleaned	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No if No, give details	

Comments

Doors/Plates Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<u>05</u> No. of doors	<input type="checkbox"/> No of Panels
Doors/Plates Installed:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels

Where Installed:

EXHAUST AND DUCT CLEANED - 10-11-2019

Duct Size & Approx. Length:	Insulated:	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Condition of Ducts:	<input checked="" type="checkbox"/> Clean	<input type="checkbox"/> Dirty	<input type="checkbox"/> Very Dirty
Damaged:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Where <input type="checkbox"/> N/A
Exhaust Fans:	<input checked="" type="checkbox"/> Upblast	<input type="checkbox"/> Inline	<input type="checkbox"/> Utility <input type="checkbox"/> Others

Location: Condition of Roof:

LAST CLEANING DATE	CURRENT CLEANING DATE	NEXT CLEANING DATE
	<u>07-11-2019</u>	<u>07.05.2020</u>

CHEMICALS AND EQUIPMENTS USED

<input checked="" type="checkbox"/> JETTING MACHINE	<input type="checkbox"/> INLET WATER HOSE	<input checked="" type="checkbox"/> EXTENTION CORDS	<input checked="" type="checkbox"/> VACCUM CLEANER
<input checked="" type="checkbox"/> LED LIGHTS	<input type="checkbox"/> PLASTICS ROLL/BAGS	<input checked="" type="checkbox"/> SUITABLE PPE	<input checked="" type="checkbox"/> DEGREASER CHEMICAL
<input checked="" type="checkbox"/> LADDER			

COMMENTS AND RECOMMENDATION:

ABOVE MENTIONED

Crystalline Representative:

Customer Representative:



& EXHAUST SYSTEM CLEANED

HARI'S

Pawan

Signature: [Signature]

Signature: [Signature]



CRYSTALLINE ENVIROMENTAL SERVICES

KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1776

CUSTOMER: <u>AFOCH - AL DHAFRA AIR BASE</u>	CONTACT PERSON: <u>PAWAN Khudiy</u>
SITE DETAILS: <u>SOLDIERS KITCHEN</u>	CONTACT NUMBER: <u>0569069615</u>
NAME OF KITCHEN: <u>MAIN KITCHEN</u>	LOCATION: <u>G. FLOOR</u>
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT	

Type & Size of Hood:

Cooking Volume:	<input checked="" type="checkbox"/> Very High	<input type="checkbox"/> High	<input type="checkbox"/> Medium	<input type="checkbox"/> Low
Type of Filters:	<input checked="" type="checkbox"/> Mesh	<input type="checkbox"/> Baffle	<input type="checkbox"/> N/A	
Filters in Place:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Filter Cleaning Freq.	<input type="checkbox"/> Daily	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/> Monthly	<input type="checkbox"/> Not Known

Comments:

Hood - 02

FIRE PROTECTION SYSTEM

Kitchen:	<input checked="" type="checkbox"/> Powder	<input type="checkbox"/> CO2	<input type="checkbox"/> Foam	<input type="checkbox"/> Other
Cooker Hoods:	<input type="checkbox"/> CO2	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Dry Powder	<input type="checkbox"/> Other
Fire Dampers:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	Fusible Links:	<input type="checkbox"/> Yes <input type="checkbox"/> No

DUCTWORK

Duct Made of:	<input checked="" type="checkbox"/> Galvanized Steel	<input type="checkbox"/> Stainless Steel	<input type="checkbox"/> Other
Physical Entry:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Access with Tools only:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Vertical Access:	<input type="checkbox"/> Rope access	<input checked="" type="checkbox"/> Safety Harness	<input type="checkbox"/> N/A
Entire System Cleaned	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No if No, give details	

Comments

Doors/Plates Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels
Doors/Plates Installed:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels

Where Installed:

EXHAUST AND DUCT CLEANED - 10-11-2019

Duct Size & Approx. Length:	Insulated:	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Condition of Ducts:	<input checked="" type="checkbox"/> Clean	<input type="checkbox"/> Dirty	<input type="checkbox"/> Very Dirty
Damaged:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Where <input type="checkbox"/> N/A
Exhaust Fans:	<input checked="" type="checkbox"/> Upblast	<input type="checkbox"/> Inline	<input type="checkbox"/> Utility <input type="checkbox"/> Others

Location:

Condition of Roof:

LAST CLEANING DATE

CURRENT CLEANING DATE

NEXT CLEANING DATE

08-11-2019

08-05-2020

CHEMICALS AND EQUIPMENTS USED

<input checked="" type="checkbox"/> JETTING MACHINE	<input checked="" type="checkbox"/> INLET WATER HOSE	<input checked="" type="checkbox"/> EXTENTION CORDS	<input checked="" type="checkbox"/> VACCUM CLEANER
<input checked="" type="checkbox"/> LED LIGHTS	<input checked="" type="checkbox"/> PLASTICS ROLL/BAGS	<input checked="" type="checkbox"/> SUITABLE PPE	<input checked="" type="checkbox"/> DEGREASER CHEMICAL
<input checked="" type="checkbox"/> LADDER			

COMMENTS AND RECOMMENDATION:

ABOVE MENTIONED

KITCHEN HOOD

& EXHAUST SYSTEM CLEANED

Crystalline Representative:

Customer Representative:



HARIS
PAWAN

Signature: HARIS

Signature: PAWAN



CRYSTALLINE ENVIROMENTAL SERVICES

KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1777

CUSTOMER: <u>AFOCH AL DHAFRA AIR BASE</u>	CONTACT PERSON: <u>PAWAN KHADKA</u>
SITE DETAILS: <u>SOLDIERS KITCHEN</u>	CONTACT NUMBER: <u>0569069015</u>
NAME OF KITCHEN: <u>PASTRY</u>	LOCATION: <u>G. FLOOR</u>
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT	

Type & Size of Hood:

Cooking Volume:	<input checked="" type="checkbox"/> Very High	<input type="checkbox"/> High	<input type="checkbox"/> Medium	<input type="checkbox"/> Low
Type of Filters:	<input checked="" type="checkbox"/> Mesh	<input type="checkbox"/> Baffle	<input type="checkbox"/> N/A	
Filters in Place:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Filter Cleaning Freq.	<input type="checkbox"/> Daily	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/> Monthly	<input type="checkbox"/> Not Known

Comments:

FIRE PROTECTION SYSTEM

Kitchen:	<input checked="" type="checkbox"/> Powder	<input type="checkbox"/> CO2	<input type="checkbox"/> Foam	<input type="checkbox"/> Other
Cooker Hoods:	<input type="checkbox"/> CO2	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Dry Powder	<input type="checkbox"/> Other
Fire Dampers:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	Fusible Links:	<input type="checkbox"/> Yes <input type="checkbox"/> No

DUCTWORK

Duct Made of:	<input type="checkbox"/> Galvanized Steel	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Other
Physical Entry:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Access with Tools only:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Vertical Access:	<input type="checkbox"/> Rope access	<input checked="" type="checkbox"/> Safety Harness	<input type="checkbox"/> N/A
Entire System Cleaned	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No if No, give details	

Comments

Doors/Plates Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels
Doors/Plates Installed:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels

Where Installed:

EXHAUST AND DUCT CLEANED - 10-11-2019

Duct Size & Approx. Length:	Insulated:	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Condition of Ducts:	<input checked="" type="checkbox"/> Clean	<input type="checkbox"/> Dirty	<input type="checkbox"/> Very Dirty
Damaged:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Where <input type="checkbox"/> N/A
Exhaust Fans:	<input checked="" type="checkbox"/> Upblast	<input type="checkbox"/> Inline	<input type="checkbox"/> Utility <input type="checkbox"/> Others

Location: Condition of Roof:

LAST CLEANING DATE	CURRENT CLEANING DATE	NEXT CLEANING DATE
	<u>07-11-2019</u>	<u>07-05-2020</u>

CHEMICALS AND EQUIPMENTS USED

<input checked="" type="checkbox"/> JETTING MACHINE	<input type="checkbox"/> INLET WATER HOSE	<input type="checkbox"/> EXTENTION CORDS	<input checked="" type="checkbox"/> VACCUM CLEANER
<input checked="" type="checkbox"/> LED LIGHTS	<input type="checkbox"/> PLASTICS ROLL/BAGS	<input type="checkbox"/> SUITABLE PPE	<input checked="" type="checkbox"/> DEGREASER CHEMICAL
<input checked="" type="checkbox"/> LADDER			

COMMENTS AND RECOMMENDATION:

ABOVE MENTIONED KITCHEN HOOD AND EXHAUST SYSTEM CLEANED

Crystalline Representative:	<u>HARIS</u>	Signature: <u>[Signature]</u>
Customer Representative:	<u>PAWAN</u>	Signature: <u>[Signature]</u>





CRYSTALLINE ENVIROMENTAL SERVICES

KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1778

CUSTOMER: <u>AFOUH-ALDHAFRA AIR BASE</u>	CONTACT PERSON: <u>PAWAN KHADKA</u>
SITE DETAILS: <u>OFFICERS KITCHEN</u>	CONTACT NUMBER: <u>0560069615</u>
NAME OF KITCHEN: <u>MAIN KITCHEN</u>	LOCATION: <u>G. FLOOR</u>
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT	

Type & Size of Hood:

Cooking Volume:	<input checked="" type="checkbox"/> Very High	<input type="checkbox"/> High	<input type="checkbox"/> Medium	<input type="checkbox"/> Low
Type of Filters:	<input checked="" type="checkbox"/> Mesh	<input type="checkbox"/> Baffle	<input type="checkbox"/> N/A	
Filters in Place:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Filter Cleaning Freq.	<input type="checkbox"/> Daily	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/> Monthly	<input type="checkbox"/> Not Known

Comments:

FIRE PROTECTION SYSTEM

Kitchen:	<input checked="" type="checkbox"/> Powder	<input type="checkbox"/> CO2	<input type="checkbox"/> Foam	<input type="checkbox"/> Other
Cooker Hoods:	<input type="checkbox"/> CO2	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Dry Powder	<input type="checkbox"/> Other
Fire Dampers:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	Fusible Links:	<input type="checkbox"/> Yes <input type="checkbox"/> No

DUCTWORK

Duct Made of:	<input type="checkbox"/> Galvanized Steel	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Other
Physical Entry:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Access with Tools only:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Partly
Vertical Access:	<input type="checkbox"/> Rope access	<input checked="" type="checkbox"/> Safety Harness	<input type="checkbox"/> N/A
Entire System Cleaned	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No if No, give details	

Comments

Doors/Plates Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels
Doors/Plates Installed:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No. of doors	<input type="checkbox"/> No of Panels

Where Installed:

Duct Size & Approx. Length:	Insulated:	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Condition of Ducts:	<input checked="" type="checkbox"/> Clean	<input type="checkbox"/> Dirty	<input type="checkbox"/> Very Dirty
Damaged:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Where <input type="checkbox"/> N/A
Exhaust Fans:	<input checked="" type="checkbox"/> Upblast	<input type="checkbox"/> Inline	<input type="checkbox"/> Utility <input type="checkbox"/> Others

Location:

Condition of Roof:

LAST CLEANING DATE

CURRENT CLEANING DATE

NEXT CLEANING DATE

11-11-2019

11-05-2019

CHEMICALS AND EQUIPMENTS USED

JETTING MACHINE INLET WATER HOSE EXTENTION CORDS VACCUM CLEANER
 LED LIGHTS PLASTICS ROLL/BAGS SUITABLE PPE DEGREASER CHEMICAL LADDER

COMMENTS AND RECOMMENDATION:

KITCHEN HOOD &



DUCT CLEANED & SERVICED

Crystalline Representative:

Customer Representative:

HARI'S
PAWAN

Signature: [Signature]

Signature: [Signature]

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CHIEF EXECUTIVE OFFICER

CLIENT NAME : ARMED FORCES OFFICERS CLUB & HOTEL
CONTACT PERSON : MS. SHAIKHA AL KHAABI
DESIGNATION : CEO
SITE DETAILS : AL DHAFRA AIR BASE, AL AIN TRUCK ROAD,
ABU DHABI.
DETAILS : KITCHEN HOOD & EXHAUST SYSTEM
CLEANING & DEGREASING
DATE OF CLEANING : 11 NOVEMBER 2019
FREQUENCY OF CLEANING : HALF YEARLY
DATE OF NEXT CLEANING : 11 MAY 2020

The above kitchen were cleaned in accordance with NFPA 96 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

The kitchen exhaust systems must be cleaned and degreased every Six-Monthly.



Tasman Pinto

CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES