


WATER TANK CLEANING & DISINFECTION COMPLETION REPORT

FOR



Client : FOUR N PROPERTY LLC.
Contact Person: Mr. Rohan Amjah
Procurement Manager.
Site Details : Al Salam Living City, Abu Dhabi.
Date : 16 April 2018



CRYSTALLINE
ENVIRONMENTAL SERVICES

CRYSTALLINE ENVIRONMENTAL
SERVICES

P.O. BOX 131463, Abu Dhabi, U.A.E.

TEL: 02 6508930 FAX: 02 6508942

info@crystalline-uae.com

www.crystalline-uae.com





CRYSTALLINE ENVIRONMENTAL SERVICES

WATER TANK - AFTER SERVICE REPORT

13044

CUSTOMER: <u>AL SALAM LIVING CITY</u>			CONTACT PERSON: <u>R. Campo</u> AL		
SITE DETAILS: <u>SALAM CITY</u>			CONTACT NO: <u>050-2210721</u>		
TANK DETAILS: <u>G.R.P. WATER TANK</u>			LOCATION DETAILS: <u>ELEVATED WATER TANK-D</u>		
TYPE OF BUILDING: <input type="checkbox"/> COMMERCIAL		<input checked="" type="checkbox"/> RESIDENTIAL		<input type="checkbox"/> OTHERS	
<u>TYPE OF TANK</u>					
<input type="checkbox"/> CONCRETE	<input checked="" type="checkbox"/> GRP PANEL	<input type="checkbox"/> FRP TANK	<input type="checkbox"/> GALVANIZED	<input type="checkbox"/> STEEL PANEL	<input type="checkbox"/> PLASTIC
<input type="checkbox"/> CONCRETE COATED		<input type="checkbox"/> POLYURETHANE	<input type="checkbox"/> OTHERS		
<u>SIZE OF TANK</u>			<u>QUANTITY OF WATER</u>		
M3	USG	L*B*H	<input type="checkbox"/> FULL	<input type="checkbox"/> HALF	<input checked="" type="checkbox"/> EMPTY
<u>CONDITION OF WATER TANK BEFORE CLEANING</u>			<u>CONDITION OF WATER TANK AFTER CLEANING</u>		
<input type="checkbox"/> CLEAN	<input checked="" type="checkbox"/> DIRTY	<input type="checkbox"/> VERY DIRTY	<input checked="" type="checkbox"/> CLEAN	<input type="checkbox"/> DIRTY	<input type="checkbox"/> VERY DIRTY
<input type="checkbox"/> BIOFILMS	<input type="checkbox"/> MOULDS	<input type="checkbox"/> SLIME	<input type="checkbox"/> BIOFILMS	<input type="checkbox"/> MOULDS	<input type="checkbox"/> SLIME
<input type="checkbox"/> SEDIMENTS	<input checked="" type="checkbox"/> MUD & SAND	<input type="checkbox"/> RUST	<input type="checkbox"/> SEDIMENTS	<input type="checkbox"/> MUD & SAND	<input type="checkbox"/> RUST
<u>ACCESS</u>		<u>MANHOLE</u>		<input type="checkbox"/> COVERED	<input type="checkbox"/> DAMAGED
<input type="checkbox"/> NA					<input type="checkbox"/> NA
<u>LADDER IN</u>		<u>LADDER OUT</u>		<u>LEAKS</u>	
<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO
<u>TANK CLEANED</u>		<u>TANK DISINFECTED</u>		<u>PIPES DISINFECTED</u>	
<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> YES	<input type="checkbox"/> NO
<u>LAST CLEANING DATE</u>		<u>CURRENT CLEANING DATE</u>		<u>NEXT CLEANING DATE</u>	
		<u>09.04.2018</u>		<u>09.10.2018</u>	
<u>CHEMICALS & EQUIPMENTS USED</u>					
1. <u>CARELO BIO</u> Quantity <u>500 ml</u>					
2. <u>CARELO BIO PLUS</u> Quantity _____					
<input checked="" type="checkbox"/> Submersibel Pump <input checked="" type="checkbox"/> High/Low Pressure Jet <input checked="" type="checkbox"/> Extension Cords <input checked="" type="checkbox"/> LED lights <input checked="" type="checkbox"/> Foot Bath <input checked="" type="checkbox"/> Ladder					
<input checked="" type="checkbox"/> Ventilating Fan <input checked="" type="checkbox"/> Suction/Discharge Hoses <input checked="" type="checkbox"/> Oxygen Meter <input checked="" type="checkbox"/> Vacuum Cleaner <input checked="" type="checkbox"/> Cleaning Materials					
<u>COMMENTS & RECOMMENDATIONS:</u>					
<u>MENTIONED WATER TANK ARE CLEANED AND DISINFECTED</u>					
Crystalline Representative: <u>HARRIS</u>			Signature: <u>HARRIS</u>		

Date of Cleaning, 09-04-2018

PHOTOGRAPHS
UNDER GROUND RCC WATER TANK - D

BEFORE



AFTER



CLEANER WATER GREENER TOMORROW

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES


CLEANING & DISINFECTION CERTIFICATE

POTABLE WATER TANKS

CLIENT NAME : FOUR N PROPERTY LLC.
CLIENT ADDRESS : P.O. BOX: 61091, ABU DHABI, UAE.
CONTACT PERSON : MR. ROHAN AMJAH.
SITE DETAILS : AL SALAM LIVING CITY, ABU DHABI, UAE.
DETAILS : WATER TANK CLEANING
DATE OF CLEANING : 04 APRIL 2018
FREQUENCY OF CLEANING : EVERY SIX MONTHS
DATE OF NEXT CLEANING : 09 OCTOBER 2018

The procedures employed in this cleaning and disinfection comply with HS (G) 70 health and safety guidelines for prevention of legionella as well as BS6700 and CARELA BIO PLUS method statement.

The entire water storage tank should be cleaned and disinfected minimum every six (6) months depending upon the condition.



CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES