

MANHOLE CLEANING & SERVICING

COMPLETION REPORT

For



Client : LINE INVESTMENTS &
PROPERTY LLC.
Contact Person: Mr. Devasia Abraham
Project Engineer.
Site Details : Al Wahda Mall, Abu Dhabi.
Date : 11 October 2018



CRYSTALLINE
ENVIRONMENTAL SERVICES

**Crystalline environmental
services**

P.O. Box 131463, Abu Dhabi, U.A.E.

Tel: 02 6508930 Fax: 02 6508942

info@crystalline-uae.com

www.crystalline-uae.com



CRYSTALLINE ENVIRONMENTAL SERVICES

1152

MANHOLE, GULLY TRAP, DRAINAGE - AFTER SERVICE REPORT

CUSTOMER:	CONTACT PERSON: Mr. Nathan
SITE DETAILS: AL WAHDA MALL	CONTACT NUMBER: 050 616 7602
NAME OF MANHOLE: A. Drain PIPE	LOCALISQTION: Lulu market Basement
TYPE OF BUILDING: <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> EDUCATIONAL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> INDUSTRIAL	

PART OF DRAINAGE

MANHOLE UNDERGROUND DRAINAGE PIPE GULLY TRAP GREASE TRAP

DRAINAGE PIPE APPARENT DRAINAGE PIPE EMBEDDED DRAINAGE PIPE

CONDITION OF MANHOLE, GULLY TRAP, DRAINAGE BEFORE CLEANING

LITTLE DIRTY DIRTY VERY DIRTY RUST SEDIMENTS MUD

BIOFILMS SLIME GREASE ROOT SAND MOULDS

OBSTRUCT BLOCK FLUENT FLOW LOW FLOW ANOTHER: _____

MANHOLE BLOCKED	GULLY TRAP BLOCKED	DRAINAGE BLOCKED	ALL BLOCKED
<input type="checkbox"/> YES <input type="checkbox"/> NO			

COMMENTS:

Apparent drainage pipe with very low flow.

MANHOLE AND GULLY TRAP COVER: COVERED DAMAGED BLOCKED ADAPTED

CONDITION OF MANHOLE, GULLY TRAP, DRAINAGE AFTER CLEANING

LITTLE CLEAN CLEAN VERY CLEAN FLUENT FLOW LOW FLOW UNBLOCK

	MANHOLE	GULLY TRAP	STORM WATER	DRAINAGE	TOTAL
NUMBER OF MANHOLE CLEANED				3	3
NUMBER OF MANHOLE BLOCKED				1	1

ACCESS

LADDER IN NO LADDER

MANHOLE CLEANED	GULLY TRAP CLEANED	DRAINAGE CLEANED	ALL DISINFECTED
<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO

SERVICES OF DATES

LAST CLEANING DATE	LAST CLEANING DATE	LAST CLEANING DATE
	7/10/2018	

CHEMICALS AND EQUIPMENTS USED

PRESSURE MACHINE JETTING MACHINE MULTIGAS DETECTEUR INLET WATER HOSE

EXTENTION CORDS VACCUM CLEANER VENTILATION FAN CLEANING MAT

LED LIGHTS PLASTICS ROLL PLASTICS BAGS SUITABLE PPE

TRIPOD AIR REPAIR 7D-A DEGREASER CHEMICAL LADDER

COMMENTS AND RECOMMENDATION:

Crystalline representative: Kennedy Wah Bahni	Signature:
Customer/Customer representative: 0554706068	Signature:

Date of Cleaning: 07-10-2018

PHOTOGRAPHS

MANHOLE CLEANING & DRAINLINE JETTING- AL WAHDA (Lulu Basement)

BEFORE CLEANING



AFTER CLEANING



Date of Cleaning: 07-10-2018


PHOTOGRAPHS

MANHOLE CLEANING & DRAINLINE JETTING- AL WAHDA (Lulu Basement)

BEFORE CLEANING



AFTER CLEANING



CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CLEANING & DISINFECTION CERTIFICATE

CLIENT NAME : LINE INVESTMENTS & PROPERTY LLC.

CLIENT ADDRESS : P.O BOX: 4048, ABU DHABI, UAE.

CONTACT PERSON : MR. DEVASIA ABRAHAM.

SITE DETAILS : AL WAHDA MALL, ABU DHABI, UAE.

DETAILS : MANHOLE & DRAINLINE CLEANING

DATE OF CLEANING : 07 OCTOBER 2018

FREQUENCY OF CLEANING : EVERY SIX MONTHS

DATE OF NEXT CLEANING : 07 APRIL 2019

The procedures employed in this cleaning and disinfection comply with Abu Dhabi Municipality guidelines

The entire Manhole & Drain Line should be cleaned and disinfected minimum every six (6) months depending upon the condition.



CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES