

**ENVIRONMENTAL  
SERVICES FOR  
A GREENER  
TOMORROW...  
ONE STEP AT  
A TIME.**



Completion Report for

## **Kitchen Hood & Exhaust System Cleaning & Degreasing**

Date: **09 January 2020**  
Client Name: **Armed Forces Officers Club & Hotel**  
Contact Person: **Ms. Shaikha Al Khaabi**  
Designation: **CEO**  
Site Detail: **PG 91, Abu Dhabi**





# CRYSTALLINE ENVIROMENTAL SERVICES

## KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1867

|   |                                    |
|---|------------------------------------|
| CUSTOMER: <u>DEEJAH DG-91</u>   | CONTACT PERSON: <u>050 3310776</u> |
| SITE DETAILS: <u>AL BATEEN AD</u>   | CONTACT NUMBER: <u>Vimal</u>       |
| NAME OF KITCHEN: <u>SIRCOOL ROYEN</u>   | LOCATION: <u>GROUND FLOOR</u>      |
| TYPE OF BUILDING: <input type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT |                                    |

Type & Size of Hood:

|                       |   |  |                                  |                                    |
|-----------------------|---|--|----------------------------------|------------------------------------|
| Cooking Volume:       | <input type="checkbox"/> Very High      | <input checked="" type="checkbox"/> High   | <input type="checkbox"/> Medium  | <input type="checkbox"/> Low       |
| Type of Filters:      | <input type="checkbox"/> Mesh           | <input checked="" type="checkbox"/> Baffle | <input type="checkbox"/> N/A     |                                    |
| Filters in Place:     | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No                | <input type="checkbox"/> N/A     |                                    |
| Filter Cleaning Freq. | <input type="checkbox"/> Daily          | <input checked="" type="checkbox"/> Weekly | <input type="checkbox"/> Monthly | <input type="checkbox"/> Not Known |

Comments:

**FIRE PROTECTION SYSTEM**

|               |  |   |                                     |   |
|---------------|--|---|-------------------------------------|---|
| Kitchen:      | <input checked="" type="checkbox"/> Powder | <input checked="" type="checkbox"/> CO2 | <input type="checkbox"/> Foam       | <input checked="" type="checkbox"/> Other                           |
| Cooker Hoods: | <input checked="" type="checkbox"/> CO2    | <input type="checkbox"/> Sprinkler      | <input type="checkbox"/> Dry Powder | <input checked="" type="checkbox"/> Other                           |
| Fire Dampers: | <input checked="" type="checkbox"/> Yes    | <input type="checkbox"/> No             | Fusible Links:                      | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |

**DUCTWORK**

|                         |  |   |  |
|-------------------------|--|---|--|
| Duct Made of:           | <input checked="" type="checkbox"/> Galvanized Steel | <input checked="" type="checkbox"/> Stainless Steel | <input type="checkbox"/> Other             |
| Physical Entry:         | <input checked="" type="checkbox"/> Yes              | <input type="checkbox"/> No                         | <input type="checkbox"/> Partly            |
| Access with Tools only: | <input type="checkbox"/> Yes                         | <input type="checkbox"/> No                         | <input checked="" type="checkbox"/> Partly |
| Vertical Access:        | <input type="checkbox"/> Rope access                 | <input checked="" type="checkbox"/> Safety Harness  | <input type="checkbox"/> N/A               |
| Entire System Cleaned   | <input checked="" type="checkbox"/> Yes              | <input type="checkbox"/> No if No, give details     |  |

Comments:

|                         |                              |  |                                       |                                       |
|-------------------------|------------------------------|--|---------------------------------------|---------------------------------------|
| Doors/Plates Present:   | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | <input type="checkbox"/> No. of doors | <input type="checkbox"/> No of Panels |
| Doors/Plates Installed: | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | <input type="checkbox"/> No. of doors | <input type="checkbox"/> No of Panels |

Where Installed:

|   |   |  |  |
|---|---|--|--|
| Duct Size & Approx. Length: <u>9-MT</u> | Insulated:                                  | <input type="checkbox"/> Yes           | <input type="checkbox"/> No                                      |
| Condition of Ducts:                     | <input checked="" type="checkbox"/> Clean   | <input type="checkbox"/> Dirty         | <input type="checkbox"/> Very Dirty                              |
| Damaged:                                | <input type="checkbox"/> Yes                | <input checked="" type="checkbox"/> No | <input type="checkbox"/> Where <input type="checkbox"/> N/A      |
| Exhaust Fans:                           | <input checked="" type="checkbox"/> Upblast | <input type="checkbox"/> Inline        | <input type="checkbox"/> Utility <input type="checkbox"/> Others |

|                           |                                |                    |
|---------------------------|--------------------------------|--------------------|
| Location: <u>ROOF TOP</u> | Condition of Roof: <u>GOOD</u> |                    |
| LAST CLEANING DATE        | CURRENT CLEANING DATE          | NEXT CLEANING DATE |
|                           | <u>08-01-2020</u>              | <u>07-06-2020</u>  |

**CHEMICALS AND EQUIPMENTS USED**

|  |  |   |  |
|--|--|---|--|
| <input type="checkbox"/> JETTING MACHINE       | <input type="checkbox"/> INLET WATER HOSE              | <input checked="" type="checkbox"/> EXTENTION CORDS | <input type="checkbox"/> VACCUM CLEANER                |
| <input checked="" type="checkbox"/> LED LIGHTS | <input checked="" type="checkbox"/> PLASTICS ROLL/BAGS | <input checked="" type="checkbox"/> SUITABLE PPE    | <input checked="" type="checkbox"/> DEGREASER CHEMICAL |
| <input checked="" type="checkbox"/> LADDER     |  |   |  |

**COMMENTS AND RECOMMENDATION:** SIRCOOL HOOD ROYEN HOOD'DUCT CLEANED. 3 NOS EXHAUST FAN CLEANED. ALL HOODS & DUCTS CLEANED AND DISINFECTED.

|  |                               |
|--|-------------------------------|
| Crystalline Representative: <u>L. ANSARY</u> | Signature: <u>[Signature]</u> |
| Customer Representative: <u>Vimal</u>        | Signature: <u>[Signature]</u> |

CLEANER WATER GREENER TOMORROW

PHOTO NOT ALLOWED.

Web: [www.crystalline-uae.com](http://www.crystalline-uae.com)  
 E-mail: [info@crystalline-uae.com](mailto:info@crystalline-uae.com)  
 Tel.: +971 55 7167017



# CRYSTALLINE ENVIROMENTAL SERVICES

## KITCHEN EXHAUST SYSTEM - AFTER SERVICE REPORT

1866

|   |  |  |   |
|---|--|--|---|
| CUSTOMER: <u>AFOCA-PG-91</u>  |  | CONTACT PERSON:                                      |   |
| SITE DETAILS: <u>AL BATEEN-ABUDHABI</u>   |  | CONTACT NUMBER:                                      |   |
| NAME OF KITCHEN: <u>HOT KITCHEN</u>   |  | LOCATION: <u>GROUND FLOOR</u>                        |   |
| TYPE OF BUILDING: <input type="checkbox"/> COMMERCIAL <input type="checkbox"/> HOTEL <input checked="" type="checkbox"/> RESIDENCIAL <input type="checkbox"/> RESTAURANT  |  |  |   |
| Type & Size of Hood: <u>DOUBLE HOOD 5MT</u>   |  |  |   |
| Cooking Volume:   |  | <input checked="" type="checkbox"/> Very High        | <input type="checkbox"/> High                       |
|   |  | <input type="checkbox"/> Medium                      | <input type="checkbox"/> Low                        |
| Type of Filters:  |  | <input type="checkbox"/> Mesh                        | <input checked="" type="checkbox"/> Baffle          |
|   |  | <input type="checkbox"/> N/A                         |   |
| Filters in Place:   |  | <input type="checkbox"/> Yes                         | <input checked="" type="checkbox"/> No              |
|   |  | <input type="checkbox"/> N/A                         |   |
| Filter Cleaning Freq.   |  | <input type="checkbox"/> Daily                       | <input checked="" type="checkbox"/> Weekly          |
|   |  | <input type="checkbox"/> Monthly                     | <input type="checkbox"/> Not Known                  |
| Comments:   |  |  |   |
| <b>FIRE PROTECTION SYSTEM</b>   |  |  |   |
| Kitchen:  |  | <input checked="" type="checkbox"/> Powder           | <input checked="" type="checkbox"/> CO2             |
|   |  | <input type="checkbox"/> Foam                        | <input checked="" type="checkbox"/> Other           |
| Cooker Hoods:   |  | <input checked="" type="checkbox"/> CO2              | <input checked="" type="checkbox"/> Sprinkler       |
|   |  | <input type="checkbox"/> Dry Powder                  | <input checked="" type="checkbox"/> Other           |
| Fire Dampers:   |  | <input type="checkbox"/> Yes                         | <input type="checkbox"/> No                         |
| Fusible Links:  |  | <input type="checkbox"/> Yes                         | <input type="checkbox"/> No                         |
| <b>DUCTWORK</b>   |  |  |   |
| Duct Made of:   |  | <input checked="" type="checkbox"/> Galvanized Steel | <input checked="" type="checkbox"/> Stainless Steel |
|   |  | <input type="checkbox"/> Other                       |   |
| Physical Entry:   |  | <input checked="" type="checkbox"/> Yes              | <input type="checkbox"/> No                         |
|   |  | <input checked="" type="checkbox"/> Partly           |   |
| Access with Tools only:   |  | <input type="checkbox"/> Yes                         | <input type="checkbox"/> No                         |
|   |  | <input type="checkbox"/> Partly                      |   |
| Vertical Access:  |  | <input type="checkbox"/> Rope access                 | <input checked="" type="checkbox"/> Safety Harness  |
|   |  | <input type="checkbox"/> N/A                         |   |
| Entire System Cleaned   |  | <input checked="" type="checkbox"/> Yes              | <input type="checkbox"/> No if No, give details     |
| Comments  |  |  |   |
| Doors/Plates Present:   |  | <input type="checkbox"/> Yes                         | <input checked="" type="checkbox"/> No              |
|   |  | <input type="checkbox"/> No. of doors                | <input type="checkbox"/> No of Panels               |
| Doors/Plates Installed:   |  | <input type="checkbox"/> Yes                         | <input checked="" type="checkbox"/> No              |
|   |  | <input type="checkbox"/> No. of doors                | <input type="checkbox"/> No of Panels               |
| Where Installed:  |  |  |   |
| Duct Size & Approx. Length: <u>7 MT</u>   |  | Insulated:   |   |
|   |  | <input type="checkbox"/> Yes                         | <input checked="" type="checkbox"/> No              |
| Condition of Ducts:   |  | <input type="checkbox"/> Clean                       | <input type="checkbox"/> Dirty                      |
|   |  | <input type="checkbox"/> Very Dirty                  |   |
| Damaged:  |  | <input type="checkbox"/> Yes                         | <input checked="" type="checkbox"/> No              |
|   |  | <input type="checkbox"/> Where                       | <input type="checkbox"/> N/A                        |
| Exhaust Fans:   |  | <input checked="" type="checkbox"/> Upblast          | <input type="checkbox"/> Inline                     |
|   |  | <input type="checkbox"/> Utility                     | <input type="checkbox"/> Others                     |
| Location: <u>ROOF TOP</u>   |  | Condition of Roof: <u>GOOD</u>                       |   |
| LAST CLEANING DATE  |  | CURRENT CLEANING DATE                                |   |
|   |  | <u>07-01-2020</u>                                    |   |
|   |  | NEXT CLEANING DATE                                   |   |
|   |  | <u>06-06-2020</u>                                    |   |
| <b>CHEMICALS AND EQUIPMENTS USED</b>  |  |  |   |
| <input type="checkbox"/> JETTING MACHINE <input type="checkbox"/> INLET WATER HOSE <input checked="" type="checkbox"/> EXTENTION CORDS <input type="checkbox"/> VACCUM CLEANER  |  |  |   |
| <input checked="" type="checkbox"/> LED LIGHTS <input checked="" type="checkbox"/> PLASTICS ROLL/BAGS <input checked="" type="checkbox"/> SUITABLE PPE <input checked="" type="checkbox"/> DEGREASER CHEMICAL <input type="checkbox"/> LADDER |  |  |   |
| <b>COMMENTS AND RECOMMENDATION:</b> <u>1 NOS DOUBLE HOOD CLEANED &amp; DISINFECTION COMPLETED -</u>   |  |  |   |
| Crystalline Representative: <u>K. ANSARI</u>  |  | Signature: <u>[Signature]</u>                        |   |
| Customer Representative:  |  | Signature: <u>[Signature]</u>                        |   |

CLEANER WATER GREENER TOMORROW

PLEASE NOTE:  
NO PHOTOS ALLOWED

Web: [www.crystalline-uae.com](http://www.crystalline-uae.com)  
E-mail: [info@crystalline-uae.com](mailto:info@crystalline-uae.com)  
Tel.: +971 55 7167017

# CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

## KITCHEN HOOD CLEANING AND DEGREASING

**CLIENT NAME** : ARMED FORCES OFFICERS CLUB & HOTEL  
**CONTACT PERSON** : MS. SHAIKHA AL KHAABI  
**DESIGNATION** : CEO  
**SITE DETAILS** : PG 91, ABU DHABI  
**DETAILS** : KITCHEN HOOD & EXHAUST SYSTEM  
CLEANING & DEGREASING  
**DATE OF CLEANING** : 08 JANUARY 2020  
**FREQUENCY OF CLEANING** : HALF YEARLY  
**DATE OF NEXT CLEANING** : 07 JULY 2020

*The above kitchen were cleaned in accordance with NFPA 96 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.*

*The kitchen exhaust systems must be cleaned and degreased every Six-Monthly.*



*Tasman Pinto*

**CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES**