

**ENVIRONMENTAL  
SERVICES FOR  
A GREENER  
TOMORROW...  
ONE STEP AT  
A TIME.**



**CRYSTALLINE**  
ENVIRONMENTAL SERVICES



Completion Report for

## **Water Tank Cleaning & Disinfection**

Date: **31 July 2019**  
Client Name: **Tafawuq Facility Management**  
Contact Person: **Mr. Jericho Delos Reyes**  
Designation: **Asst. Facility Manager**  
Site Detail: **Al Bateen Park, Abu Dhabi**





# CRYSTALLINE ENVIRONMENTAL SERVICES

## WATER TANK - AFTER SERVICE REPORT


16776

CUSTOMER: <i>Tafany FM</i>			CONTACT PERSON: <i>M.R. Joby</i>		
SITE DETAILS: <i>A. Bateem park</i>			CONTACT NO: <i>0565229670</i>		
TANK DETAILS: <i>RCC water Tank-01</i>			LOCATION DETAILS: <i>Common Area ground</i>		
TYPE OF BUILDING: <input type="checkbox"/> COMMERCIAL		<input checked="" type="checkbox"/> RESIDENTIAL		<input type="checkbox"/> OTHERS	
<b>TYPE OF TANK</b>					
<input checked="" type="checkbox"/> CONCRETE	<input type="checkbox"/> GRP PANEL	<input type="checkbox"/> FRP TANK	<input type="checkbox"/> GALVANIZED	<input type="checkbox"/> STEEL PANEL	<input type="checkbox"/> PLASTIC
<input type="checkbox"/> CONCRETE COATED	<input type="checkbox"/> POLYURETHANE	<input type="checkbox"/> OTHERS			
<b>SIZE OF TANK</b>			<b>QUANTITY OF WATER</b>		
M3	USG	L*B*H	<input type="checkbox"/> FULL	<input checked="" type="checkbox"/> HALF	<input type="checkbox"/> EMPTY
<b>CONDITION OF WATER TANK BEFORE CLEANING</b>			<b>CONDITION OF WATER TANK AFTER CLEANING</b>		
<input type="checkbox"/> CLEAN	<input checked="" type="checkbox"/> DIRTY	<input type="checkbox"/> VERY DIRTY	<input checked="" type="checkbox"/> CLEAN	<input type="checkbox"/> DIRTY	<input type="checkbox"/> VERY DIRTY
<input type="checkbox"/> BIOFILMS	<input type="checkbox"/> MOULDS	<input type="checkbox"/> SLIME	<input type="checkbox"/> BIOFILMS	<input type="checkbox"/> MOULDS	<input type="checkbox"/> SLIME
<input type="checkbox"/> SEDIMENTS	<input checked="" type="checkbox"/> MUD & SAND	<input type="checkbox"/> RUST	<input type="checkbox"/> SEDIMENTS	<input type="checkbox"/> MUD & SAND	<input type="checkbox"/> RUST
<b>ACCESS</b>		<b>MANHOLE</b>		<input type="checkbox"/> COVERED	<input type="checkbox"/> DAMAGED
<input type="checkbox"/> NA					
<b>LADDER IN</b>	<b>LADDER OUT</b>	<b>LEAKS</b>	<b>DRAIN LINE</b>	<b>VALVES</b>	<b>FLOAT VALVE</b>
<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
<b>TANK CLEANED</b>		<b>TANK DISINFECTED</b>		<b>PIPES DISINFECTED</b>	
<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> YES	<input type="checkbox"/> NO <input checked="" type="checkbox"/> NA
<b>LAST CLEANING DATE</b>		<b>CURRENT CLEANING DATE</b>		<b>NEXT CLEANING DATE</b>	
		<i>22/07/2019</i>		<i>22/06/2020</i>	
<b>CHEMICALS &amp; EQUIPMENTS USED</b>					
1. <i>Carda bio and plus</i> Quantity <i>100 ml</i>					
2. _____ Quantity _____					
<input checked="" type="checkbox"/> Submersibel Pump <input checked="" type="checkbox"/> High/Low Pressure Jet <input type="checkbox"/> Extension Cords <input checked="" type="checkbox"/> LED lights <input checked="" type="checkbox"/> Foot Bath <input checked="" type="checkbox"/> Ladder <input checked="" type="checkbox"/> Ventilating Fan <input checked="" type="checkbox"/> Suction/Discharge Hoses <input checked="" type="checkbox"/> Oxygen Meter <input checked="" type="checkbox"/> Vacuum Cleaner <input checked="" type="checkbox"/> Cleaning Materials					
<b>COMMENTS AND RECOMMENDATION:</b>					
<i>water Tank cleaned and disinfected and completed</i>					
Crystalline representative: <i>Bishal Rai</i>			Signature: _____		
Customer/Customer representative: <i>Arun kumar. G</i>			Signature: <i>Arun 22/7/19</i>		

Date of Cleaning: 22-07-2019

**PHOTOGRAPHS**  
**GROUND LEVEL RCC WATER TANK**

**BEFORE**



**AFTER**



# CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

## CLEANING & DISINFECTION OF WATER TANK

**CLIENT NAME** : TAFAWUQ FACILITY MANAGEMENT

**CONTACT PERSON** : MR. JERICHO DELOS REYES

**DESIGNATION** : ASST. FACILITY MANAGER

**SITE DETAILS** : AL BATEEN PARK, ABU DHABI

**DETAILS** : WATER TANK CLEANING & DISINFECTION

**DATE OF CLEANING** : 22 JULY 2019

**FREQUENCY OF CLEANING** : HALF YEARLY

**DATE OF NEXT CLEANING** : 21 JANUARY 2020

*The above water tanks were cleaned and disinfected in accordance with the Code of Practice for the inspection and cleaning of customer water storage tanks.*



*Ismanpinto*

**CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES**