

SEWAGE SUMP PIT TANK CLEANING

COMPLETION REPORT

For

HYATT
CAPITAL
GATE
ABU DHABI

Client: HYATT CAPITAL GATE
Contact: Mr. Mandeep Sharma
Person: Assistant Director of Engineering
Site Details: Hyatt Capital Gate, Abu Dhabi.
Date: 10 May 2018



CRYSTALLINE
ENVIRONMENTAL SERVICES

**Crystalline environmental
services**

P.O. Box 131463, Abu Dhabi, U.A.E.

Tel: 02 6508930 Fax: 02 6508942

info@crystalline-uae.com

www.crystalline-uae.com

Clea




Date of Cleaning: 30-04-2018

PHOTOGRAPHS
CLEANING AND SERVICING OF SEWERAGE SUMP PIT (M.E. ROOM)

BEFORE



AFTER





CRYSTALLINE
ENVIRONMENTAL SERVICES

Date of Cleaning: 30-04-2018

PHOTOGRAPHS
CLEANING AND SERVICING OF SEWERAGE SUMP PIT (PLANT. ROOM)

BEFORE



AFTER



CLEANER WATER GREENER TOMORROW

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CLEANING & DISINFECTION CERTIFICATE

SUMP PIT WATER TANKS

CLIENT NAME : HYATT CAPITAL GATE, ABU DHABI
CLIENT ADDRESS : P.O. BOX: 95165, ABU DHABI, UAE.
CONTACT PERSON : MR. MANDEEP SHARMA.
SITE DETAILS : HYATT CAPITAL GATE, ABU DHABI.
DETAILS : SEWERAGE SUMP PIT CLEANING
DATE OF CLEANING : 30 APRIL 2018
FREQUENCY OF CLEANING : EVERY FOUR MONTHS
DATE OF NEXT CLEANING : 30 AUGUST 2018

The procedures employed in this cleaning and disinfection comply with HS (G) 70 health and safety guidelines for prevention of legionella as well as BS6700 and CARELA BIO PLUS method statement.

The entire Sewerage Sump Pit tank should be cleaned and disinfected minimum every four (4) months depending upon the condition.



CRYSTALLINE CLEANING AND ENVIRONMENTAL SERVICES